



architektura <sup>PLC</sup>

P.O. Box 791  
Grand Haven, MI 49417

# PROJECT MANUAL

**PROJECT MANUAL FOR:**  
**UNION HIGH SCHOOL – HEALTH CENTER RENOVATIONS**  
1800 TREMONT BLVD NW, GRAND RAPIDS MI 49504

**OWNER:**  
GRAND RAPIDS PUBLIC SCHOOLS

**PREPARED BY:**  
ARCHITEKTURA PLC  
PO BOX 971  
GRAND HAVEN, MI 49417

**PROJECT #**  
1342

**ISSUANCE:**  
2 JUNE 2025 FOR BIDS AND PERMITS



This document has been prepared by architektura <sup>PLC</sup> as an instrument of service, and architektura <sup>PLC</sup> shall retain all common law, statutory and other reserved rights, including the copyright thereto.

**SECTION 000110  
TABLE OF CONTENTS**

**SPECIFICATIONS**

**1.01 DIVISION 01 -- GENERAL REQUIREMENTS**

- A. 013000 - Administrative Requirements
- B. 014000 - Quality Requirements
- C. 016000 - Product Requirements
- D. 017000 - Execution and Closeout Requirements

**1.02 DIVISION 02 -- EXISTING CONDITIONS**

**1.03 DIVISION 03 -- CONCRETE**

**1.04 DIVISION 04 -- MASONRY**

**1.05 DIVISION 05 -- METALS**

**1.06 DIVISION 06 -- WOOD, PLASTICS, AND COMPOSITES**

- A. 061000 - Rough Carpentry
- B. 064100 - Architectural Wood Casework

**1.07 DIVISION 07 -- THERMAL AND MOISTURE PROTECTION**

- A. 078400 - Firestopping
- B. 079200 - Joint Sealants

**1.08 DIVISION 08 -- OPENINGS**

- A. 081113 - Hollow Metal Doors and Frames
- B. 081416 - Flush Wood Doors

**1.09 DIVISION 09 -- FINISHES**

- A. 092116 - Gypsum Board Assemblies
- B. 095100 - Acoustical Ceilings
- C. 096500 - Resilient Flooring
- D. 096813 - Tile Carpeting
- E. 099123 - Interior Painting

**1.10 DIVISION 10 -- SPECIALTIES**

- A. 102600 - Wall and Door Protection
- B. 104400 - Fire Protection Specialties

**1.11 DIVISION 11 -- EQUIPMENT**

**1.12 DIVISION 12 -- FURNISHINGS**

- A. 123600 - Countertops

- 1.13 DIVISION 13 -- SPECIAL CONSTRUCTION
- 1.14 DIVISION 14 -- CONVEYING EQUIPMENT
- 1.15 DIVISION 21 -- FIRE SUPPRESSION
- 1.16 DIVISION 22 -- PLUMBING
- 1.17 DIVISION 23 -- HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)
- 1.18 DIVISION 25 -- INTEGRATED AUTOMATION
- 1.19 DIVISION 26 -- ELECTRICAL
- 1.20 DIVISION 27 -- COMMUNICATIONS
- 1.21 DIVISION 28 -- ELECTRONIC SAFETY AND SECURITY
- 1.22 DIVISION 31 -- EARTHWORK
- 1.23 DIVISION 32 -- EXTERIOR IMPROVEMENTS
- 1.24 DIVISION 33 -- UTILITIES
- 1.25 DIVISION 34 -- TRANSPORTATION
- 1.26 DIVISION 40 -- PROCESS INTEGRATION
- 1.27 DIVISION 46 -- WATER AND WASTEWATER EQUIPMENT

**SECTION 013000  
ADMINISTRATIVE REQUIREMENTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. General administrative requirements.
- B. Electronic document submittal service.
- C. Submittals for review, information, and project closeout.
- D. Number of copies of submittals.
- E. Requests for Interpretation (RFI) procedures.
- F. Submittal procedures.

**1.02 RELATED REQUIREMENTS**

- A. Section 016000 - Product Requirements: General product requirements.
- B. Section 017000 - Execution and Closeout Requirements: Additional coordination requirements.
- C. Section 017800 - Closeout Submittals: Project record documents; operation and maintenance data; warranties and bonds.

**1.03 GENERAL ADMINISTRATIVE REQUIREMENTS**

- A. Comply with requirements of Section 017000 - Execution and Closeout Requirements for coordination of execution of administrative tasks with timing of construction activities.

**1.04 PROJECT COORDINATOR**

- A. Project Coordinator: GENERAL CONTRACTOR.
- B. Cooperate with the Project Coordinator in allocation of mobilization areas of site; for field offices and sheds, for site access, traffic, and parking facilities.
- C. During construction, coordinate use of site and facilities through the Project Coordinator.
- D. Comply with Project Coordinator's procedures for intra-project communications; submittals, reports and records, schedules, coordination drawings, and recommendations; and resolution of ambiguities and conflicts.
- E. Comply with instructions of the Project Coordinator for use of temporary utilities and construction facilities.
- F. Coordinate field engineering and layout work under instructions of the Project Coordinator.
- G. Make the following types of submittals to Architect through the Project Coordinator:
  - 1. Requests for Interpretation.
  - 2. Requests for substitution.
  - 3. Shop drawings, product data, and samples.
  - 4. Test and inspection reports.
  - 5. Design data.
  - 6. Manufacturer's instructions and field reports.
  - 7. Applications for payment and change order requests.
  - 8. Coordination drawings.
  - 9. Correction Punch List and Final Correction Punch List for Substantial Completion.
  - 10. Closeout submittals.

**PART 2 PRODUCTS - NOT USED**

**PART 3 EXECUTION**

**3.01 ELECTRONIC DOCUMENT SUBMITTAL SERVICE**

- A. All documents transmitted for purposes of administration of the contract are to be in electronic (PDF, MS Word, or MS Excel) format, as appropriate to the document, and transmitted via an

Internet-based submittal service that receives, logs and stores documents, provides electronic stamping and signatures, and notifies addressees via email.

1. Besides submittals for review, information, and closeout, this procedure applies to Requests for Interpretation (RFIs), progress documentation, contract modification documents (e.g. supplementary instructions, change proposals, change orders), applications for payment, field reports and meeting minutes, Contractor's correction punchlist, and any other document any participant wishes to make part of the project record.
  2. Contractor and Architect are required to use this service.
  3. It is Contractor's responsibility to submit documents in allowable format.
  4. Subcontractors, suppliers, and Architect's consultants will be permitted to use the service at no extra charge.
  5. Users of the service need an email address, internet access, and PDF review software that includes ability to mark up and apply electronic stamps (such as Adobe Acrobat, [www.adobe.com](http://www.adobe.com), or Bluebeam PDF Revu, [www.bluebeam.com](http://www.bluebeam.com)), unless such software capability is provided by the service provider.
  6. Paper document transmittals will not be reviewed; emailed electronic documents will not be reviewed.
  7. All other specified submittal and document transmission procedures apply, except that electronic document requirements do not apply to samples or color selection charts.
- B. Submittal Service: The selected service is:
- C. Training: One, one-hour, web-based training session will be arranged for all participants, with representatives of Architect and Contractor participating; further training is the responsibility of the user of the service.
- D. Project Closeout: Architect will determine when to terminate the service for the project and is responsible for obtaining archive copies of files for Owner.

### **3.02 REQUESTS FOR INTERPRETATION (RFI)**

- A. Definition: A request seeking one of the following:
1. An interpretation, amplification, or clarification of some requirement of Contract Documents arising from inability to determine from them the exact material, process, or system to be installed; or when the elements of construction are required to occupy the same space (interference); or when an item of work is described differently at more than one place in Contract Documents.
  2. A resolution to an issue which has arisen due to field conditions and affects design intent.
- B. Whenever possible, request clarifications at the next appropriate project progress meeting, with response entered into meeting minutes, rendering unnecessary the issuance of a formal RFI.
- C. Preparation: Prepare an RFI immediately upon discovery of a need for interpretation of Contract Documents. Failure to submit a RFI in a timely manner is not a legitimate cause for claiming additional costs or delays in execution of the work.
1. Prepare a separate RFI for each specific item.
    - a. Review, coordinate, and comment on requests originating with subcontractors and/or materials suppliers.
    - b. Do not forward requests which solely require internal coordination between subcontractors.
  2. Prepare in a format and with content acceptable to Owner.
  3. Prepare using software provided by the Electronic Document Submittal Service.
  4. Combine RFI and its attachments into a single electronic file. PDF format is preferred.
- D. Reason for the RFI: Prior to initiation of an RFI, carefully study all Contract Documents to confirm that information sufficient for their interpretation is definitely not included.
1. Include in each request Contractor's signature attesting to good faith effort to determine from Contract Documents information requiring interpretation.
  2. Unacceptable Uses for RFIs: Do not use RFIs to request the following::

- a. Approval of substitutions (see Section - 016000 - Product Requirements)
  - b. Changes that entail change in Contract Time and Contract Sum (comply with provisions of the Conditions of the Contract).
  - c. Different methods of performing work than those indicated in the Contract Drawings and Specifications (comply with provisions of the Conditions of the Contract).
- 3. Improper RFIs: Requests not prepared in compliance with requirements of this section, and/or missing key information required to render an actionable response. They will be returned without a response, with an explanatory notation.
- 4. Frivolous RFIs: Requests regarding information that is clearly indicated on, or reasonably inferable from, Contract Documents, with no additional input required to clarify the question. They will be returned without a response, with an explanatory notation.
  - a. The Owner reserves the right to assess the Contractor for the costs (on time-and-materials basis) incurred by the Architect, and any of its consultants, due to processing of such RFIs.
- E. Content: Include identifiers necessary for tracking the status of each RFI, and information necessary to provide an actionable response.
  - 1. Official Project name and number, and any additional required identifiers established in Contract Documents.
  - 2. Contractor's suggested resolution: A written and/or a graphic solution, to scale, is required in cases where clarification of coordination issues is involved, for example; routing, clearances, and/or specific locations of work shown diagrammatically in Contract Documents. If applicable, state the likely impact of the suggested resolution on Contract Time or the Contract Sum.
- F. Attachments: Include sketches, coordination drawings, descriptions, photos, submittals, and other information necessary to substantiate the reason for the request.
- G. Review Time: Architect will respond and return RFIs to Contractor within seven calendar days of receipt. For the purpose of establishing the start of the mandated response period, RFIs received after 12:00 noon will be considered as having been received on the following regular working day.
  - 1. Response period may be shortened or lengthened for specific items, subject to mutual agreement, and recorded in a timely manner in progress meeting minutes.
- H. Responses: Content of answered RFIs will not constitute in any manner a directive or authorization to perform extra work or delay the project. If in Contractor's belief it is likely to lead to a change to Contract Sum or Contract Time, promptly issue a notice to this effect, and follow up with an appropriate Change Order request to Owner.

### **3.03 SUBMITTALS FOR REVIEW**

- A. When the following are specified in individual sections, submit them for review:
  - 1. Product data.
  - 2. Shop drawings.
  - 3. Samples for selection.
  - 4. Samples for verification.
- B. Submit to Architect for review for the limited purpose of checking for compliance with information given and the design concept expressed in Contract Documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 017800 - Closeout Submittals.

### **3.04 SUBMITTALS FOR INFORMATION**

- A. When the following are specified in individual sections, submit them for information:
  - 1. Design data.
  - 2. Certificates.

3. Test reports.
4. Inspection reports.
5. Manufacturer's instructions.
6. Manufacturer's field reports.
7. Other types indicated.

B. Submit for Architect's knowledge as contract administrator or for Owner.

### **3.05 SUBMITTALS FOR PROJECT CLOSEOUT**

- A. Submit Correction Punch List for Substantial Completion.
- B. Submit Final Correction Punch List for Substantial Completion.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 017800 - Closeout Submittals:
  1. Project record documents.
  2. Operation and maintenance data.
  3. Warranties.
  4. Bonds.
  5. Other types as indicated.
- D. Submit for Owner's benefit during and after project completion.

### **3.06 NUMBER OF COPIES OF SUBMITTALS**

- A. Electronic Documents: Submit one electronic copy in PDF format; an electronically-marked up file will be returned. Create PDFs at native size and right-side up; illegible files will be rejected.
- B. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect.
  1. After review, produce duplicates.
  2. Retained samples will not be returned to Contractor unless specifically so stated.

### **3.07 SUBMITTAL PROCEDURES**

- A. General Requirements:
  1. Use a separate transmittal for each item.
  2. Submit separate packages of submittals for review and submittals for information, when included in the same specification section.
  3. Transmit using approved form.
    - a. Use Contractor's form, subject to prior approval by Architect.
  4. Sequentially identify each item. For revised submittals use original number and a sequential numerical suffix.
  5. Identify: Project; Contractor; subcontractor or supplier; pertinent drawing and detail number; and specification section number and article/paragraph, as appropriate on each copy.
  6. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of products required, field dimensions, adjacent construction work, and coordination of information is in accordance with the requirements of the work and Contract Documents.
  7. Schedule submittals to expedite the Project, and coordinate submission of related items.
    - a. For each submittal for review, allow 10 days excluding delivery time to and from the Contractor.
    - b. For sequential reviews involving Architect's consultants, Owner, or another affected party, allow an additional 7 days.
  8. Provide space for Contractor and Architect review stamps.
  9. When revised for resubmission, identify all changes made since previous submission.
  10. Distribute reviewed submittals. Instruct parties to promptly report inability to comply with requirements.
  11. Incomplete submittals will not be reviewed, unless they are partial submittals for distinct portion(s) of the work, and have received prior approval for their use.

12. Submittals not requested will be recognized, and will be returned "Not Reviewed",
- B. Product Data Procedures:
  1. Submit only information required by individual specification sections.
  2. Collect required information into a single submittal.
  3. Do not submit (Material) Safety Data Sheets for materials or products.
- C. Shop Drawing Procedures:
  1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting Contract Documents and coordinating related work.
  2. Do not reproduce Contract Documents to create shop drawings.
  3. Generic, non-project-specific information submitted as shop drawings do not meet the requirements for shop drawings.
- D. Samples Procedures:
  1. Transmit related items together as single package.
  2. Identify each item to allow review for applicability in relation to shop drawings showing installation locations.
  3. Include with transmittal high-resolution image files of samples to facilitate electronic review and approval. Provide separate submittal page for each item image.

### **3.08 SUBMITTAL REVIEW**

- A. Submittals for Review: Architect will review each submittal, and approve, or take other appropriate action.
- B. Submittals for Information: Architect will acknowledge receipt and review. See below for actions to be taken.
- C. Architect's actions will be reflected by marking each returned submittal using virtual stamp on electronic submittals.
- D. Architect's and consultants' actions on items submitted for review:
  1. Authorizing purchasing, fabrication, delivery, and installation:
    - a. "Approved", or language with same legal meaning.
    - b. "Approved as Noted, Resubmission not required", or language with same legal meaning.
      - 1) At Contractor's option, submit corrected item, with review notations acknowledged and incorporated.
    - c. "Approved as Noted, Resubmit for Record", or language with same legal meaning.
  2. Not Authorizing fabrication, delivery, and installation:
- E. Architect's and consultants' actions on items submitted for information:
  1. Items for which no action was taken:
    - a. "Received" - to notify the Contractor that the submittal has been received for record only.
  2. Items for which action was taken:
    - a. "Reviewed" - no further action is required from Contractor.

### **END OF SECTION**



**SECTION 014000  
QUALITY REQUIREMENTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Submittals.
- B. Quality assurance.
- C. Testing and inspection agencies and services.
- D. Control of installation.
- E. Defect Assessment.

**1.02 RELATED REQUIREMENTS**

- A. Section 013000 - Administrative Requirements: Submittal procedures.
- B. Section 016000 - Product Requirements: Requirements for material and product quality.

**1.03 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.

**1.04 TESTING AND INSPECTION AGENCIES AND SERVICES**

**PART 3 EXECUTION**

**2.01 CONTROL OF INSTALLATION**

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from Architect before proceeding.
- D. Comply with specified standards as minimum quality for the work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

**2.02 TESTING AND INSPECTION**

- A. Testing Agency Duties:
  - 1. Provide qualified personnel at site. Cooperate with Architect and Contractor in performance of services.
  - 2. Perform specified sampling and testing of products in accordance with specified standards.
  - 3. Ascertain compliance of materials and mixes with requirements of Contract Documents.
  - 4. Promptly notify Architect and Contractor of observed irregularities or non-compliance of Work or products.
  - 5. Perform additional tests and inspections required by Architect.
  - 6. Submit reports of all tests/inspections specified.
- B. Limits on Testing/Inspection Agency Authority:
  - 1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
  - 2. Agency may not approve or accept any portion of the Work.
  - 3. Agency may not assume any duties of Contractor.

4. Agency has no authority to stop the Work.
- C. Contractor Responsibilities:
  1. Deliver to agency at designated location, adequate samples of materials proposed to be used that require testing, along with proposed mix designs.
  2. Cooperate with laboratory personnel, and provide access to the Work and to manufacturers' facilities.
  3. Provide incidental labor and facilities:
    - a. To provide access to Work to be tested/inspected.
    - b. To obtain and handle samples at the site or at source of Products to be tested/inspected.
    - c. To facilitate tests/inspections.
    - d. To provide storage and curing of test samples.
  4. Notify Architect and laboratory 24 hours prior to expected time for operations requiring testing/inspection services.
  5. Employ services of an independent qualified testing laboratory and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
  6. Arrange with Owner's agency and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
- D. Re-testing required because of non-compliance with specified requirements shall be performed by the same agency on instructions by Architect.
- E. Re-testing required because of non-compliance with specified requirements shall be paid for by Contractor.

### **2.03 DEFECT ASSESSMENT**

- A. Replace Work or portions of the Work not complying with specified requirements.

**END OF SECTION**

**SECTION 016000  
PRODUCT REQUIREMENTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. General product requirements.
- B. Transportation, handling, storage and protection.
- C. Product option requirements.
- D. Substitution limitations.
- E. Procedures for Owner-supplied products.
- F. Maintenance materials, including extra materials, spare parts, tools, and software.

**1.02 SUBMITTALS**

- A. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- B. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- C. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
  - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.

**PART 2 PRODUCTS**

**2.01 NEW PRODUCTS**

- A. Provide new products unless specifically required or permitted by Contract Documents.
- B. Use of products having any of the following characteristics is not permitted:
  - 1. Made using or containing CFC's or HCFC's.
  - 2. Containing lead, cadmium, or asbestos.
- C. Where other criteria are met, Contractor shall give preference to products that:
  - 1. If used on interior, have lower emissions, as defined in Section 016116.
  - 2. If wet-applied, have lower VOC content, as defined in Section 016116.

**2.02 PRODUCT OPTIONS**

- A. Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, no options or substitutions allowed.
- C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for substitution for any manufacturer not named.

**2.03 MAINTENANCE MATERIALS**

- A. Furnish extra materials, spare parts, tools, and software of types and in quantities specified in individual specification sections.
- B. Deliver to Project site; obtain receipt prior to final payment.

**PART 3 EXECUTION**

**3.01 OWNER-SUPPLIED PRODUCTS**

- A. Owner's Responsibilities:

1. Arrange for and deliver Owner reviewed shop drawings, product data, and samples, to Contractor.
  2. Arrange and pay for product delivery to site.
  3. On delivery, inspect products jointly with Contractor.
  4. Submit claims for transportation damage and replace damaged, defective, or deficient items.
  5. Arrange for manufacturers' warranties, inspections, and service.
- B. Contractor's Responsibilities:
1. Review Owner reviewed shop drawings, product data, and samples.
  2. Receive and unload products at site; inspect for completeness or damage jointly with Owner.
  3. Handle, store, install and finish products.
  4. Repair or replace items damaged after receipt.

### **3.02 TRANSPORTATION AND HANDLING**

- A. Package products for shipment in manner to prevent damage; for equipment, package to avoid loss of factory calibration.
- B. If special precautions are required, attach instructions prominently and legibly on outside of packaging.
- C. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.
- D. Transport and handle products in accordance with manufacturer's instructions.
- E. Transport materials in covered trucks to prevent contamination of product and littering of surrounding areas.
- F. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- G. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- H. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

### **3.03 STORAGE AND PROTECTION**

- A. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication. See Section 017419.
- B. Store and protect products in accordance with manufacturers' instructions.
- C. Store with seals and labels intact and legible.
- D. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- E. For exterior storage of fabricated products, place on sloped supports above ground.
- F. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
- G. Comply with manufacturer's warranty conditions, if any.
- H. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- I. Prevent contact with material that may cause corrosion, discoloration, or staining.
- J. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.

- K. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.

**END OF SECTION**

**SECTION 017000  
EXECUTION AND CLOSEOUT REQUIREMENTS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition, except removal, disposal, and/or remediation of hazardous materials and toxic substances.
- C. Pre-installation meetings.
- D. Cutting and patching.
- E. Surveying for laying out the work.
- F. Cleaning and protection.
- G. Starting of systems and equipment.
- H. Demonstration and instruction of Owner personnel.
- I. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.
- J. General requirements for maintenance service.

**1.02 RELATED REQUIREMENTS**

- A. Section 013000 - Administrative Requirements: Submittals procedures, Electronic document submittal service.
- B. Section 015000 - Temporary Facilities and Controls: Temporary exterior enclosures.
- C. Section 015000 - Temporary Facilities and Controls: Temporary interior partitions.
- D. Section 017800 - Closeout Submittals: Project record documents, operation and maintenance data, warranties, and bonds.
- E. Section 024100 - Demolition: Demolition of whole structures and parts thereof; site utility demolition.
- F. Section 078400 - Firestopping.

**1.03 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.
- B. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
  - 1. Structural integrity of any element of Project.
  - 2. Integrity of weather exposed or moisture resistant element.
  - 3. Efficiency, maintenance, or safety of any operational element.
  - 4. Visual qualities of sight exposed elements.
  - 5. Work of Owner or separate Contractor.
- C. Project Record Documents: Accurately record actual locations of capped and active utilities.

**1.04 PROJECT CONDITIONS**

- A. Use of explosives is not permitted.
- B. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.
- C. Dust Control: Execute work by methods to minimize raising dust from construction operations. Provide positive means to prevent air-borne dust from dispersing into atmosphere and over adjacent property.
  - 1. Provide dust-proof barriers between construction areas and areas continuing to be occupied by Owner.

- D. Noise Control: Provide methods, means, and facilities to minimize noise produced by construction operations.
  - 1. Outdoors: Limit conduct of especially noisy exterior work to the hours of 8 am to 5 pm.
  - 2. Indoors: Limit conduct of especially noisy interior work to the hours of 6 pm to 7 am.
- E. Rodent Control: Provide methods, means, and facilities to prevent rodents from accessing or invading premises.
- F. Pollution Control: Provide methods, means, and facilities to prevent contamination of soil, water, and atmosphere from discharge of noxious, toxic substances, and pollutants produced by construction operations. Comply with federal, state, and local regulations.

## **1.05 COORDINATION**

- A. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- B. Notify affected utility companies and comply with their requirements.
- C. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- D. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- E. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- F. Coordinate completion and clean-up of work of separate sections.
- G. After Owner occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

## **PART 2 PRODUCTS**

### **2.01 PATCHING MATERIALS**

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 016000 - Product Requirements.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.
- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.

- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

### **3.02 PREPARATION**

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

### **3.03 PREINSTALLATION MEETINGS**

- A. When required in individual specification sections, convene a preinstallation meeting at the site prior to commencing work of the section.
- B. Require attendance of parties directly affecting, or affected by, work of the specific section.
- C. Notify Architect four days in advance of meeting date.
- D. Prepare agenda and preside at meeting:
  - 1. Review conditions of examination, preparation and installation procedures.
  - 2. Review coordination with related work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

### **3.04 GENERAL INSTALLATION REQUIREMENTS**

- A. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- B. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- C. Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- D. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- E. Make neat transitions between different surfaces, maintaining texture and appearance.

### **3.05 ALTERATIONS**

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
  - 1. Verify that construction and utility arrangements are as indicated.
  - 2. Report discrepancies to Architect before disturbing existing installation.
  - 3. Beginning of alterations work constitutes acceptance of existing conditions.
- B. Keep areas in which alterations are being conducted separated from other areas that are still occupied.
  - 1. Provide, erect, and maintain temporary dustproof partitions of construction indicated on drawings .
- C. Remove existing work as indicated and as required to accomplish new work.
  - 1. Remove items indicated on drawings.
  - 2. Relocate items indicated on drawings.
  - 3. Where new surface finishes are to be applied to existing work, perform removals, patch, and prepare existing surfaces as required to receive new finish; remove existing finish if necessary for successful application of new finish.
  - 4. Where new surface finishes are not specified or indicated, patch holes and damaged surfaces to match adjacent finished surfaces as closely as possible.



- D. Services (Including but not limited to HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications): Remove, relocate, and extend existing systems to accommodate new construction.
  - 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components; if necessary, modify installation to allow access or provide access panel.
  - 2. Where existing systems or equipment are not active and Contract Documents require reactivation, put back into operational condition; repair supply, distribution, and equipment as required.
  - 3. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
    - a. Disable existing systems only to make switchovers and connections; minimize duration of outages.
    - b. Provide temporary connections as required to maintain existing systems in service.
  - 4. Verify that abandoned services serve only abandoned facilities.
  - 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings; remove back to source of supply where possible, otherwise cap stub and tag with identification; patch holes left by removal using materials specified for new construction.
- E. Protect existing work to remain.
  - 1. Prevent movement of structure; provide shoring and bracing if necessary.
  - 2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
  - 3. Repair adjacent construction and finishes damaged during removal work.
- F. Adapt existing work to fit new work: Make as neat and smooth transition as possible.
  - 1. When existing finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect.
  - 2. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
- G. Patching: Where the existing surface is not indicated to be refinished, patch to match the surface finish that existed prior to cutting. Where the surface is indicated to be refinished, patch so that the substrate is ready for the new finish.
- H. Refinish existing surfaces as indicated:
  - 1. Where rooms or spaces are indicated to be refinished, refinish all visible existing surfaces to remain to the specified condition for each material, with a neat transition to adjacent finishes.
  - 2. If mechanical or electrical work is exposed accidentally during the work, re-cover and refinish to match.
- I. Clean existing systems and equipment.
- J. Do not begin new construction in alterations areas before demolition is complete.
- K. Comply with all other applicable requirements of this section.

### **3.06 CUTTING AND PATCHING**

- A. Whenever possible, execute the work by methods that avoid cutting or patching.
- B. See Alterations article above for additional requirements.
- C. Perform whatever cutting and patching is necessary to:
  - 1. Complete the work.
  - 2. Fit products together to integrate with other work.
  - 3. Provide openings for penetration of mechanical, electrical, and other services.
  - 4. Match work that has been cut to adjacent work.
  - 5. Repair areas adjacent to cuts to required condition.

6. Repair new work damaged by subsequent work.
  7. Remove samples of installed work for testing when requested.
  8. Remove and replace defective and non-complying work.
- D. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
  - E. Employ original installer to perform cutting for weather exposed and moisture resistant elements, and sight exposed surfaces.
  - F. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
  - G. Restore work with new products in accordance with requirements of Contract Documents.
  - H. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
  - I. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Section 078400, to full thickness of the penetrated element.
  - J. Patching:
    1. Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
    2. Match color, texture, and appearance.
    3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

### **3.07 PROGRESS CLEANING**

- A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.
- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site periodically and dispose off-site; do not burn or bury.

### **3.08 PROTECTION OF INSTALLED WORK**

- A. Protect installed work from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- E. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- F. Protect work from spilled liquids. If work is exposed to spilled liquids, immediately remove protective coverings, dry out work, and replace protective coverings.
- G. Prohibit traffic or storage upon waterproofed or roofed surfaces. If traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- H. Prohibit traffic from landscaped areas.
- I. Remove protective coverings when no longer needed; reuse or recycle coverings if possible.

### **3.09 SYSTEM STARTUP**

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Verify that each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, and for conditions that may cause damage.
- C. Verify tests, meter readings, and specified electrical characteristics agree with those required by the equipment or system manufacturer.
- D. Verify that wiring and support components for equipment are complete and tested.
- E. Execute start-up under supervision of applicable Contractor personnel and manufacturer's representative in accordance with manufacturers' instructions.
- F. When specified in individual specification Sections, require manufacturer to provide authorized representative to be present at site to inspect, check, and approve equipment or system installation prior to start-up, and to supervise placing equipment or system in operation.
- G. Submit a written report that equipment or system has been properly installed and is functioning correctly.

### **3.10 DEMONSTRATION AND INSTRUCTION**

- A. Demonstrate operation and maintenance of products to Owner's personnel two weeks prior to date of Substantial Completion.
- B. Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, maintenance, and shutdown of each item of equipment at scheduled time, at equipment location.
- C. For equipment or systems requiring seasonal operation, perform demonstration for other season within six months.
- D. Provide a qualified person who is knowledgeable about the Project to perform demonstration and instruction of Owner's personnel.

### **3.11 ADJUSTING**

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.

### **3.12 FINAL CLEANING**

- A. Use cleaning materials that are nonhazardous.
- B. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- C. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- D. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- E. Clean filters of operating equipment.
- F. Clean debris from roofs, gutters, downspouts, scuppers, overflow drains, area drains, and drainage systems.
- G. Clean site; sweep paved areas, rake clean landscaped surfaces.
- H. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner; do not burn or bury.

### **3.13 CLOSEOUT PROCEDURES**

- A. Make submittals that are required by governing or other authorities.
  - 1. Provide copies to Architect.
- B. Accompany Project Coordinator on preliminary inspection to determine items to be listed for completion or correction in the Contractor's Correction Punch List for Contractor's Notice of Substantial Completion.

- C. Notify Architect when work is considered ready for Architect's Substantial Completion inspection.
- D. Submit written certification containing Contractor's Correction Punch List, that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with Contract Documents and ready for Architect's Substantial Completion inspection.
- E. Conduct Substantial Completion inspection and create Final Correction Punch List containing Architect's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect.
- F. Correct items of work listed in Final Correction Punch List and comply with requirements for access to Owner-occupied areas.
- G. Notify Architect when work is considered finally complete and ready for Architect's Substantial Completion final inspection.
- H. Complete items of work determined by Architect listed in executed Certificate of Substantial Completion.

#### **3.14 MAINTENANCE**

- A. Provide service and maintenance of components indicated in specification sections.
- B. Maintenance Period: As indicated in specification sections or, if not indicated, not less than one year from the Date of Substantial Completion or the length of the specified warranty, whichever is longer.
- C. Examine system components at a frequency consistent with reliable operation. Clean, adjust, and lubricate as required.
- D. Include systematic examination, adjustment, and lubrication of components. Repair or replace parts whenever required. Use parts produced by the manufacturer of the original component.
- E. Maintenance service shall not be assigned or transferred to any agent or subcontractor without prior written consent of the Owner.

**END OF SECTION**

**SECTION 061000  
ROUGH CARPENTRY**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Structural dimension lumber framing.
- B. Nonstructural dimension lumber framing.
- C. Rough opening framing for doors, windows, and roof openings.
- D. Sheathing.
- E. Roof-mounted curbs.
- F. Roofing nailers.
- G. Preservative treated wood materials.
- H. Fire retardant treated wood materials.
- I. Communications and electrical room mounting boards.
- J. Miscellaneous wood nailers, furring, and grounds.

**1.02 RELATED REQUIREMENTS**

- A. Section 051200 - Structural Steel Framing: Prefabricated beams and columns for support of wood framing.
- B. Section 055000 - Metal Fabrications: Miscellaneous steel connectors and support angles for wood framing.
- C. Section 061753 - Shop-Fabricated Wood Trusses.
- D. Section 092116 - Gypsum Board Assemblies: Gypsum-based sheathing.

**1.03 REFERENCE STANDARDS**

- A. ANSI A208.1 - American National Standard for Particleboard; 2022.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- C. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- D. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2017.
- E. ASTM D2898 - Standard Practice for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing; 2010 (Reapproved 2017).
- F. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber; 2021.
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023.
- H. AWC (WFCM) - Wood Frame Construction Manual for One- and Two-Family Dwellings; 2024, with Errata.
- I. AWP A U1 - Use Category System: User Specification for Treated Wood; 2022.
- J. PS 1 - Structural Plywood; 2023.
- K. PS 2 - Performance Standard for Wood Structural Panels; 2018.
- L. PS 20 - American Softwood Lumber Standard; 2021.
- M. WPA G-5 - Western Lumber Grading Rules; 2021.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide technical data on insulated sheathing, wood preservative materials, and application instructions.
- C. Manufacturer's Certificate: Certify that wood products supplied for rough carpentry meet or exceed specified requirements.
- D. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.

#### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.
- B. Fire Retardant Treated Wood: Prevent exposure to precipitation during shipping, storage, and installation.

### **PART 2 PRODUCTS**

#### **2.01 GENERAL REQUIREMENTS**

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
  - 1. If no species is specified, provide species graded by the agency specified; if no grading agency is specified, provide lumber graded by grading agency meeting the specified requirements.
  - 2. Grading Agency: Grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee at [www.alsc.org](http://www.alsc.org), and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.
  - 3. Lumber of other species or grades is acceptable provided structural and appearance characteristics are equivalent to or better than products specified.
- B. Lumber salvaged from deconstruction or demolition of existing buildings or structures is permitted in lieu of sustainably harvested lumber provided it is clean, denailed, and free of paint and finish materials, and other contamination; identify source.

#### **2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS**

- A. Grading Agency: Western Wood Products Association; WWPA G-5.
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19.
- D. Stud Framing (2 by 2 through 2 by 6 (50 by 50 mm through 50 by 150 mm) ):
  - 1. Species: Allowed under referenced grading rules.
  - 2. Grade: No. 2.
- E. Joist, Rafter, and Small Beam Framing (2 by 6 through 4 by 16 (50 by 150 mm through 100 by 400 mm) ):
  - 1. Machine stress-rated (MSR) as follows:
    - a. Fb-single; minimum extreme fiber stress in bending: 1350 psi (9,300 kPa).
    - b. E; minimum modulus of elasticity: 1,300,000 psi (8960 MPa).
  - 2. Species: Allowed under grading rules.
- F. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:
  - 1. Lumber: S4S, No. 2 or Standard Grade.
  - 2. Boards: Standard or No. 3.

#### **2.03 STRUCTURAL COMPOSITE LUMBER**

- A. At Contractor's option, structural composite lumber may be substituted for concealed dimension lumber and timbers.

- B. Structural Composite Lumber: Factory fabricated beams, headers, and columns, of sizes and types indicated on drawings; structural capacity as published by manufacturer.
  - 1. Products:
    - a. Boise Cascade Company: [www.bc.com/#sle](http://www.bc.com/#sle).
    - b. Weyerhaeuser Company: [www.weyerhaeuser.com/#sle](http://www.weyerhaeuser.com/#sle).
    - c. Substitutions: See Section 016000 - Product Requirements.

#### **2.04 CONSTRUCTION PANELS**

- A. Subflooring: Particleboard, ANSI A208.1, Grade M-2 EXTERIOR GLUE waferboard; 3/4 inch (19 mm) thick, square edge.
- B. Roof Sheathing: PS 2 type, rated Structural I Sheathing.
  - 1. Bond Classification: Exterior.
  - 2. Span Rating: 60.
  - 3. Performance Category: 3/4 PERF CAT.
- C. Wall Sheathing: Glass mat faced gypsum, ASTM C1177/C1177M, 5/8 inch Type X fire resistant (16 mm Type X fire resistant).
  - 1. At Assemblies Indicated with Fire-Rating: Use type required by indicated tested assembly.
  - 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  - 3. Edges: Square.
  - 4. Products:
    - a. CertainTeed Corporation; GlasRoc Brand: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
    - b. Georgia-Pacific Gypsum; DensGlass Sheathing: [www.gpgypsum.com/#sle](http://www.gpgypsum.com/#sle).
    - c. USG Corporation; Securock Brand Glass-Mat Sheathing Regular 5/8 in. (15.9 mm): [www.usg.com/#sle](http://www.usg.com/#sle).
    - d. Substitutions: See Section 016000 - Product Requirements.

#### **2.05 ACCESSORIES**

- A. Fasteners and Anchors:
  - 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere.
  - 2. Drywall Screws: Bugle head, hardened steel, power driven type, length three times thickness of sheathing.
- B. Die-Stamped Connectors: Hot dipped galvanized steel, sized to suit framing conditions.
  - 1. For contact with preservative treated wood in exposed locations, provide minimum G185 (Z550) galvanizing complying with ASTM A653/A653M.
- C. Joist Hangers: Hot dipped galvanized steel, sized to suit framing conditions.
  - 1. For contact with preservative treated wood in exposed locations, provide minimum G185 (Z550) galvanizing complying with ASTM A653/A653M.
- D. Sill Gasket on Top of Foundation Wall: 1/4 inch (6 mm) thick, plate width, closed cell plastic foam from continuous rolls.

#### **2.06 FACTORY WOOD TREATMENT**

- A. Treated Lumber and Plywood: Comply with requirements of AWWA U1 - Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.
  - 1. Fire-Retardant Treated Wood: Mark each piece of wood with producer's stamp indicating compliance with specified requirements.
  - 2. Preservative-Treated Wood: Provide lumber and plywood marked or stamped by an ALSC-accredited testing agency, certifying level and type of treatment in accordance with AWWA standards.
- B. Fire Retardant Treatment:

1. Exterior Type: AWP A U1, Category UCFB, Commodity Specification H, chemically treated and pressure impregnated; capable of providing a maximum flame spread index of 25 when tested in accordance with ASTM E84, with no evidence of significant combustion when test is extended for an additional 20 minutes both before and after accelerated weathering test performed in accordance with ASTM D2898.
    - a. Kiln dry wood after treatment to a maximum moisture content of 19 percent for lumber and 15 percent for plywood.
    - b. Do not use treated wood in direct contact with the ground.
  2. Interior Type A: AWP A U1, Use Category UCFA, Commodity Specification H, low temperature (low hygroscopic) type, chemically treated and pressure impregnated; capable of providing a maximum flame spread index of 25 when tested in accordance with ASTM E84, with no evidence of significant combustion when test is extended for an additional 20 minutes.
    - a. Kiln dry wood after treatment to a maximum moisture content of 19 percent for lumber and 15 percent for plywood.
    - b. Treat rough carpentry items as indicated .
    - c. Do not use treated wood in applications exposed to weather or where the wood may become wet.
- C. Preservative Treatment:
1. Products:
    - a. Lonza Group: [www.wolmanizedwood.com/#sle](http://www.wolmanizedwood.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.
  2. Preservative Pressure Treatment of Plywood Above Grade: AWP A U1, Use Category UC2 and UC3B, Commodity Specification F using waterborne preservative.
    - a. Kiln dry plywood after treatment to maximum moisture content of 19 percent.

## **PART 3 EXECUTION**

### **3.01 PREPARATION**

- A. Install sill gasket under sill plate of framed walls bearing on foundations; puncture gasket cleanly to fit tightly around protruding anchor bolts.
- B. Coordinate installation of rough carpentry members specified in other sections.

### **3.02 INSTALLATION - GENERAL**

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

### **3.03 FRAMING INSTALLATION**

- A. Set structural members level, plumb, and true to line. Discard pieces with defects that would lower required strength or result in unacceptable appearance of exposed members.
- B. Make provisions for temporary construction loads, and provide temporary bracing sufficient to maintain structure in true alignment and safe condition until completion of erection and installation of permanent bracing.
- C. Install structural members full length without splices unless otherwise specifically detailed.
- D. Comply with member sizes, spacing, and configurations indicated, and fastener size and spacing indicated, but not less than required by applicable codes and AWC (WFCM) Wood Frame Construction Manual.
- E. Construct double joist headers at floor and ceiling openings and under wall stud partitions that are parallel to floor joists; use metal joist hangers unless otherwise detailed.
- F. Frame wall openings with two or more studs at each jamb; support headers on cripple studs.



### **3.04 BLOCKING, NAILERS, AND SUPPORTS**

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to authorities having jurisdiction may be used in lieu of solid wood blocking.
- C. In metal stud walls, provide continuous blocking around door and window openings for anchorage of frames, securely attached to stud framing.
- D. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.
- E. Where ceiling-mounting is indicated, provide blocking and supplementary supports above ceiling, unless other method of support is explicitly indicated.
- F. Provide the following specific nonstructural framing and blocking:
  - 1. Cabinets and shelf supports.
  - 2. Wall brackets.
  - 3. Handrails.
  - 4. Grab bars.
  - 5. Towel and bath accessories.
  - 6. Wall-mounted door stops.
  - 7. Chalkboards and marker boards.
  - 8. Wall paneling and trim.
  - 9. Joints of rigid wall coverings that occur between studs.

### **3.05 ROOF-RELATED CARPENTRY**

- A. Coordinate installation of roofing carpentry with deck construction, framing of roof openings, and roofing assembly installation.
- B. Provide wood curb at each roof opening except where prefabricated curbs are specified and where specifically indicated otherwise; form corners by alternating lapping side members.

### **3.06 INSTALLATION OF CONSTRUCTION PANELS**

- A. Subflooring: Glue and nail to framing; staples are not permitted.
- B. Roof Sheathing: Secure panels with long dimension perpendicular to framing members, with ends staggered and over firm bearing.
  - 1. At long edges use sheathing clips where joints occur between roof framing members.
  - 2. Nail panels to framing; staples are not permitted.
- C. Wall Sheathing: Secure with long dimension perpendicular to wall studs, with ends over firm bearing and staggered, using nails, screws, or staples.
- D. Communications and Electrical Room Mounting Boards: Secure with screws to studs with edges over firm bearing; space fasteners at maximum 24 inches (610 mm) on center on all edges and into studs in field of board.
  - 1. At fire-rated walls, install board over wall board indicated as part of the fire-rated assembly.
  - 2. Where boards are indicated as full floor-to-ceiling height, install with long edge of board parallel to studs.
  - 3. Install adjacent boards without gaps.

**END OF SECTION**

**SECTION 064100**  
**ARCHITECTURAL WOOD CASEWORK**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Specially fabricated cabinet units.
- B. Hardware.

**1.02 RELATED REQUIREMENTS**

- A. Section 061000 - Rough Carpentry: Support framing, grounds, and concealed blocking.
- B. Section 123600 - Countertops.

**1.03 REFERENCE STANDARDS**

- A. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards, 2nd Edition; 2014, with Errata (2016).
- B. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards; 2021, with Errata.
- C. BHMA A156.9 - Cabinet Hardware; 2020.
- D. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Shop Drawings: Indicate materials, component profiles, fastening methods, jointing details, and accessories.
  - 1. Scale of Drawings: 1-1/2 inch to 1 foot (125 mm to 1 m), minimum.
- C. Product Data: Provide data for hardware accessories.
- D. Samples: Submit actual samples of architectural cabinet construction, minimum 12 inches (300 mm) square, illustrating proposed cabinet, countertop, and shelf unit substrate and finish.

**1.05 QUALITY ASSURANCE**

- A. Fabricator Qualifications: Company specializing in fabricating the products specified in this section with minimum five years of documented experience.
  - 1. Single Source Responsibility: Provide and install this work from single fabricator.

**1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Protect units from moisture damage.

**1.07 FIELD CONDITIONS**

- A. During and after installation of custom cabinets, maintain temperature and humidity conditions in building spaces at same levels planned for occupancy.

**PART 2 PRODUCTS**

**2.01 CABINETS**

- A. Quality Standard: Custom Grade, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
- B. Plastic Laminate Faced Cabinets: Custom grade.
- C. Cabinets:
  - 1. Finish - Exposed Exterior Surfaces: Decorative laminate.
  - 2. Finish - Exposed Interior Surfaces: Decorative laminate.
  - 3. Finish - Semi-Exposed Surfaces: Wood
  - 4. Finish - Concealed Surfaces: Manufacturer's option.
  - 5. Door and Drawer Front Edge Profiles: Square edge with thin applied band.
  - 6. Door and Drawer Front Retention Profiles: Fixed panel.

7. Casework Construction Type: Type A - Frameless.
8. Interface Style for Cabinet and Door: Style 1 - Overlay; reveal overlay.
9. Grained Face Layout for Cabinet and Door Fronts: Flush panel.
  - a. Custom Grade: Doors, drawer fronts and false fronts wood grain to run and match vertically within each cabinet unit.
10. Adjustable Shelf Loading: 50 psf (24.4 gm/sq cm).
  - a. Deflection: L/144.
11. Cabinet Style: Flush overlay.
12. Cabinet Doors and Drawer Fronts: Flush style.
13. Drawer Construction Technique: Dovetail joints.

## **2.02 WOOD-BASED COMPONENTS**

- A. Wood fabricated from old growth timber is not permitted.

## **2.03 LAMINATE MATERIALS**

- A. Manufacturers:
  1. Arborite; ColorEdge: [www.arborite.com/#sle](http://www.arborite.com/#sle).
  2. Formica Corporation: [www.formica.com/#sle](http://www.formica.com/#sle).
  3. Panolam Industries International, Inc: [www.panolam.com/#sle](http://www.panolam.com/#sle).
  4. Wilsonart LLC: [www.wilsonart.com/#sle](http://www.wilsonart.com/#sle).
  5. Substitutions: See Section 016000 - Product Requirements.
- B. High Pressure Decorative Laminate (HPDL): NEMA LD 3, types as recommended for specific applications.
- C. Provide specific types as indicated.
  1. Horizontal Surfaces: HGS, 0.048 inch (1.22 mm) nominal thickness, through color, colors as indicated, finish as indicated.
  2. Vertical Surfaces: VGS, 0.028 inch (0.71 mm) nominal thickness, through color, colors as indicated, finish as indicated.
  3. Cabinet Liner: CLS, 0.020 inch (0.51 mm) nominal thickness, through color, \_\_\_\_\_ color, finish as indicated.
  4. Laminate Backer: BKL, 0.020 inch (0.51 mm) nominal thickness, undecorated; for application to concealed backside of panels faced with high pressure decorative laminate.

## **2.04 ACCESSORIES**

- A. Adhesive: Type recommended by fabricator to suit application.
- B. Plastic Edge Banding: Extruded PVC, flat shaped; smooth finish; self locking serrated tongue; of width to match component thickness.
  1. Color: As selected by Architect from manufacturer's full range.
- C. Fasteners: Size and type to suit application.
- D. Concealed Joint Fasteners: Threaded steel.
- E. Grommets: Standard plastic, painted metal, or rubber grommets for cut-outs, in color to match adjacent surface.

## **2.05 HARDWARE**

- A. Hardware: BHMA A156.9, types as recommended by fabricator for quality grade specified.
- B. Adjustable Shelf Supports: Standard side-mounted system using recessed metal shelf standards or multiple holes for pin supports and coordinated self rests, polished chrome finish, for nominal 1 inch (25 mm) spacing adjustments.
- C. Drawer and Door Pulls: "U" shaped wire pull, steel with chrome finish, 4 inch centers ("U" shaped wire pull, steel with chrome finish, 100 mm centers).
- D. Keyed Cabinet Locks: Keyed cylinder, two keys per lock, master keyed, steel with chrome finish.

- E. Cabinet Catches and Latches:
  - 1. Type: Touch latch.
- F. Drawer Slides:
  - 1. Type: Extension types as indicated.
  - 2. Static Load Capacity: Commercial grade.
  - 3. Mounting: Side mounted.
  - 4. Features: Provide self closing/stay closed type.
  - 5. Manufacturers:
    - a. Blum, Inc; MOVENTO: [www.blum.com/#sle](http://www.blum.com/#sle).
    - b. Blum, Inc; TANDEM: [www.blum.com/#sle](http://www.blum.com/#sle).
    - c. Grass America Inc: [www.grassusa.com/#sle](http://www.grassusa.com/#sle).
    - d. Substitutions: See Section 016000 - Product Requirements.

## **2.06 FABRICATION**

- A. Assembly: Shop assemble cabinets for delivery to site in units easily handled and to permit passage through building openings.
- B. Edging: Fit shelves, doors, and exposed edges with specified edging. Do not use more than one piece for any single length.
- C. Fitting: When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide matching trim for scribing and site cutting.
- D. Plastic Laminate: Apply plastic laminate finish in full uninterrupted sheets consistent with manufactured sizes. Fit corners and joints hairline; secure with concealed fasteners. Locate counter butt joints minimum 2 feet from sink cut-outs. (Locate counter butt joints minimum 600 mm from sink cut-outs.)
  - 1. Apply laminate backing sheet to reverse side of plastic laminate finished surfaces.
- E. Provide cutouts for plumbing fixtures. Verify locations of cutouts from on-site dimensions. Prime paint cut edges.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify adequacy of backing and support framing.
- B. Verify location and sizes of utility rough-in associated with work of this section.

### **3.02 INSTALLATION**

- A. Install work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS) requirements for grade indicated.
- B. Set and secure custom cabinets in place, assuring that they are rigid, plumb, and level.
- C. Use fixture attachments in concealed locations for wall mounted components.
- D. Use concealed joint fasteners to align and secure adjoining cabinet units.
- E. Carefully scribe casework abutting other components, with maximum gaps of 1/32 inch (0.79 mm). Do not use additional overlay trim for this purpose.
- F. Secure cabinets to floor using appropriate angles and anchorages.

### **3.03 ADJUSTING**

- A. Adjust installed work.
- B. Adjust moving or operating parts to function smoothly and correctly.

### **3.04 CLEANING**

- A. Clean casework, counters, shelves, hardware, fittings, and fixtures.

## **END OF SECTION**

## **SECTION 078400 FIRESTOPPING**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Firestopping systems.
- B. Firestopping of joints and penetrations in fire-resistance-rated and smoke-resistant assemblies, whether indicated on drawings or not, and other openings indicated.

#### **1.02 RELATED REQUIREMENTS**

- A. Section 017000 - Execution and Closeout Requirements: Cutting and patching.

#### **1.03 REFERENCE STANDARDS**

- A. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2022.
- B. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2013a (Reapproved 2017).
- C. ASTM E1966 - Standard Test Method for Fire-Resistive Joint Systems; 2015 (Reapproved 2019).
- D. ASTM E2307 - Standard Test Method for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale, Multi-story Test Apparatus; 2020.
- E. ASTM E2837 - Standard Test Method for Determining the Fire Resistance of Continuity Head-of-Wall Joint Systems Installed Between Rated Wall Assemblies and Nonrated Horizontal Assemblies; 2013 (Reapproved 2017).
- F. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).
- G. ITS (DIR) - Directory of Listed Products; Current Edition.
- H. FM 4991 - Approval Standard of Firestop Contractors; 2013.
- I. FM (AG) - FM Approval Guide; Current Edition.
- J. SCAQMD 1168 - Adhesive and Sealant Applications; 1989, with Amendment (2022).
- K. UL 1479 - Standard for Fire Tests of Penetration Firestops; Current Edition, Including All Revisions.
- L. UL 2079 - Standard for Tests for Fire Resistance of Building Joint Systems; Current Edition, Including All Revisions.
- M. UL (DIR) - Online Certifications Directory; Current Edition.
- N. UL (FRD) - Fire Resistance Directory; Current Edition.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Schedule of Firestopping: List each type of penetration, fire rating of the penetrated assembly, and firestopping test or design number.
- C. Product Data: Provide data on product characteristics, performance ratings, and limitations.
- D. Manufacturer's Installation Instructions: Indicate preparation and installation instructions.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Installer's qualification statement.

#### **1.05 QUALITY ASSURANCE**

- A. Fire Testing: Provide firestopping assemblies of designs that provide the scheduled fire ratings when tested in accordance with methods indicated.

1. Listing in UL (FRD), FM (AG), or ITS (DIR) will be considered as constituting an acceptable test report.
  2. Valid evaluation report published by ICC Evaluation Service, Inc. (ICC-ES) at [www.icc-es.org](http://www.icc-es.org) will be considered as constituting an acceptable test report.
- B. Installer Qualifications: Company specializing in performing the work of this section and:
1. Approved by Factory Mutual Research Corporation under FM 4991, or meeting any two of the following requirements:
  2. Verification of minimum three years documented experience installing work of this type.
  3. Verification of at least five satisfactorily completed projects of comparable size and type.
  4. Licensed by local authorities having jurisdiction (AHJ).

## **1.06 FIELD CONDITIONS**

- A. Comply with firestopping manufacturer's recommendations for temperature and conditions during and after installation; maintain minimum temperature before, during, and for three days after installation of materials.
- B. Provide ventilation in areas where solvent-cured materials are being installed.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Firestopping Manufacturers:
1. 3M Fire Protection Products: [www.3m.com/firestop/#sle](http://www.3m.com/firestop/#sle).
  2. Hilti, Inc: [www.hilti.com/#sle](http://www.hilti.com/#sle).
  3. Specified Technologies Inc: [www.stifirestop.com/#sle](http://www.stifirestop.com/#sle).
  4. Tremco Commercial Sealants & Waterproofing; TREMstop Acrylic: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  5. Substitutions: See Section 016000 - Product Requirements.

### **2.02 MATERIALS**

- A. Firestopping Materials: Any materials meeting requirements.
- B. Mold and Mildew Resistance: Provide firestopping materials with mold and mildew resistance rating of zero(0) in accordance with ASTM G21.
- C. Primers, Sleeves, Forms, Insulation, Packing, Stuffing, and Accessories: Provide type of materials as required for tested firestopping assembly.
- D. Fire Ratings: Refer to drawings for required systems and ratings.

### **2.03 FIRESTOPPING ASSEMBLY REQUIREMENTS**

- A. Perimeter Fire Containment Firestopping: Use system that has been tested according to ASTM E2307 to have fire resistance F Rating equal to required fire rating of floor assembly.
1. Movement: Provide systems that have been tested to show movement capability as indicated.
  2. Temperature Rise: Provide systems that have been tested to show T Rating as indicated.
  3. Air Leakage: Provide systems that have been tested to show L Rating as indicated.
  4. Where floor assembly is not required to have a fire rating, provide systems that have been tested to show L Rating as indicated.
- B. Head-of-Wall (HW) Joint System Firestopping at Joints Between Fire-Rated Wall Assemblies and Non-Rated Horizontal Assemblies: Use system that has been tested according to ASTM E2837 to have fire resistance F Rating equal to required fire rating of wall assembly.
1. Movement: Provide systems that have been tested to show movement capability as indicated.
- C. Floor-to-Floor (FF), Floor-to-Wall (FW), Head-of-Wall (HW), and Wall-to-Wall (WW) Joints, Except Perimeter, Where Both Are Fire-Rated: Use system that has been tested according to ASTM E1966 or UL 2079 to have fire resistance F Rating equal to required fire rating of the assembly in which the joint occurs.

1. Movement: Provide systems that have been tested to show movement capability as indicated.
  2. Air Leakage: Provide systems that have been tested to show L Rating as indicated.
  3. Listing by FM (AG), ITS (DIR), UL (DIR), or UL (FRD) in their certification directories will be considered evidence of successful testing.
- D. Through Penetration Firestopping: Use system that has been tested according to ASTM E814 to have fire resistance F Rating equal to required fire rating of penetrated assembly.
1. Temperature Rise: Provide systems that have been tested to show T Rating as indicated.
  2. Air Leakage: Provide systems that have been tested to show L Rating as indicated.
  3. Listing by FM (AG), ITS (DIR), UL (DIR), or UL (FRD) in their certification directories will be considered evidence of successful testing.

#### **2.04 FIRESTOPPING FOR PERIMETER CONTAINMENT**

- A. Perimeter Joint Systems That Have Not Been Tested For Movement Capabilities (Static-S):
1. 2 Hour Construction: UL System CW-S-0002; Specified Technologies Inc. AS200 Elastomeric Spray.
- B. Perimeter Joint Systems That Have Movement Capabilities (Dynamic-D):
1. 3 Hour Construction: UL System CW-D-2005; Specified Technologies Inc. Fast Tack Firestop Spray.
  2. 2 Hour Construction: UL System CW-D-1004; Specified Technologies Inc. AS200 Elastomeric Spray.

#### **2.05 FIRESTOPPING FOR FLOOR-TO-FLOOR, FLOOR-TO-WALL, HEAD-OF-WALL, AND WALL-TO-WALL JOINTS**

- A. Concrete and Concrete Masonry Walls and Floors:
1. Floor-to-Floor Joints:
    - a. 3 Hour Construction: UL System FF-D-1008; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
  2. Head-of-Wall Joints at Concrete/Concrete Masonry Wall to Concrete Over Metal Deck Floor:
    - a. 2 Hour Construction: UL System HW-D-0039; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
  3. Head-of-Wall Joints at Concrete/Concrete Masonry Wall to Concrete Floor:
    - a. 3 Hour Construction: UL System HW-D-0041; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
  4. Concrete/Concrete Masonry Wall-to-Wall Joint Systems That Have Not Been Tested For Movement Capabilities (Static-S):
    - a. 3 Hour Construction: UL System WW-S-0038; Specified Technologies Inc. SIL Silicone Sealant.
  5. Concrete/Concrete Masonry Wall-to-Wall Joint Systems That Have Movement Capabilities (Dynamic-D):
    - a. 3 Hour Construction: UL System WW-D-1001; Specified Technologies Inc. SIL Silicone Sealant.
- B. Gypsum Board Walls:
1. Wall-to-Wall Joints That Have Not Been Tested For Movement Capabilities (Static-S):
    - a. 2 Hour Construction: UL System WW-S-0063; Specified Technologies Inc. SpeedFlex TTG Track Top Gasket.
  2. Wall-to-Wall Joints That Have Movement Capabilities (Dynamic-D):
    - a. 2 Hour Construction: UL System WW-D-0180; Specified Technologies Inc. SpeedFlex TTG Track Top Gasket.
  3. Head-of-Wall Joints at Underside of Steel Beam and Concrete Over Metal Deck Floor with Sprayed On Fireproofing:
    - a. 2 Hour Construction: UL System HW-D-0252; Specified Technologies Inc. AS200 Elastomeric Spray.

4. Head-of-Wall Joints at Underside of Flat Concrete:
  - a. 2 Hour Construction: UL System HW-D-0079; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
5. Head-of-Wall Joints at Concrete Over Metal Deck:
  - a. 2 Hour Construction: UL System HW-D-0034; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
6. Head-of-Wall Joints at Concrete Over Metal Deck, Wall Parallel to Ribs:
  - a. 2 Hour Construction: UL System HW-D-0184; Hilti CP 606 Flexible Firestop Sealant.
7. Head-of-Wall Joints at Concrete Over Metal Deck, Wall Perpendicular to Ribs, Cut to Fit Ribs:
  - a. 2 Hour Construction: UL System HW-D-0103; Specified Technologies Inc. ES Elastomeric Firestop Sealant.
8. Head-of-Wall Joints at Concrete Over Metal Deck, Wall Perpendicular to Ribs, Not Cut to Fit:
  - a. 2 Hour Construction: UL System HW-D-0045; Hilti CP 606 Flexible Firestop Sealant.

## **2.06 FIRESTOPPING FOR FLOOR-TO-WALL MOVABLE JOINTS**

- A. Floor-To-Wall Joint System That Have Movement Capabilities (Dynamic-D):
  1. 3 Hour Construction: UL System FW-D-1007; Specified Technologies Inc. ES Elastomeric Firestop Sealant.

## **2.07 FIRESTOPPING PENETRATIONS THROUGH GYPSUM BOARD WALLS**

- A. Blank Openings:
  1. 2 Hour Construction: UL System W-L-0032; Specified Technologies Inc. FP Intumescent Firestop Plug.
- B. Penetrations By:
  1. Multiple Penetrations in Large Openings:
    - a. 2 Hour Construction: UL System W-L-8050; Specified Technologies Inc. SSB Intumescent Firestop Pillows.
  2. Uninsulated Metallic Pipe, Conduit, and Tubing:
    - a. 2 Hour Construction: UL System W-L-1049; Specified Technologies Inc. SSS Intumescent Firestop Sealant.
  3. Uninsulated Non-Metallic Pipe, Conduit, and Tubing:
    - a. 2 Hour Construction: UL System W-L-2048; Specified Technologies Inc. SSW Wrap Strips.
  4. Electrical Cables Not In Conduit:
    - a. 2 Hour Construction: UL System W-L-3076; Specified Technologies Inc. SSS Intumescent Firestop Sealant.
  5. Cable Trays with Electrical Cables:
    - a. 2 Hour Construction: UL System W-L-4008; Specified Technologies Inc. SSB Intumescent Firestop Pillows.
  6. Insulated Pipes:
    - a. 2 Hour Construction: UL System W-L-5014; Specified Technologies Inc. SSS Intumescent Firestop Sealant.
  7. HVAC Ducts, Insulated:
    - a. 2 Hour Construction: UL System W-L-7164; Specified Technologies Inc. FyreFlange HVAC Firestop Angle.

## **2.08 FIRESTOPPING SYSTEMS**

- A. Firestopping: Any material meeting requirements.
  1. Fire Ratings: Use system that is listed by FM (AG), ITS (DIR), or UL (FRD) and tested in accordance with ASTM E814, ASTM E119, or UL 1479 with F Rating equal to fire rating of penetrated assembly and minimum T Rating Equal to F Rating and in compliance with other specified requirements.



## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify openings are ready to receive the work of this section.

### **3.02 PREPARATION**

- A. Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other materials that could adversely affect bond of firestopping material.
- B. Remove incompatible materials that could adversely affect bond.
- C. Install damming materials to prevent liquid material from leakage.

### **3.03 INSTALLATION**

- A. Install materials in manner described in fire test report and in accordance with manufacturer's instructions, completely closing openings.
- B. Do not cover installed firestopping until inspected by authorities having jurisdiction.

### **3.04 CLEANING**

- A. Clean adjacent surfaces of firestopping materials.

### **3.05 PROTECTION**

- A. Protect adjacent surfaces from damage by material installation.

**END OF SECTION**

## **SECTION 079200 JOINT SEALANTS**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Nonsag gunnable joint sealants.
- B. Joint backings and accessories.

#### **1.02 RELATED REQUIREMENTS**

- A. Section 092116 - Gypsum Board Assemblies: Sealing acoustical and sound-rated walls and ceilings.

#### **1.03 REFERENCE STANDARDS**

- A. ASTM C661 - Standard Test Method for Indentation Hardness of Elastomeric-Type Sealants by Means of a Durometer; 2015 (Reapproved 2022).
- B. ASTM C834 - Standard Specification for Latex Sealants; 2017.
- C. ASTM C881/C881M - Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete; 2020a.
- D. ASTM C919 - Standard Practice for Use of Sealants in Acoustical Applications; 2022.
- E. ASTM C920 - Standard Specification for Elastomeric Joint Sealants; 2018.
- F. ASTM C1193 - Standard Guide for Use of Joint Sealants; 2016.
- G. ASTM C1248 - Standard Test Method for Staining of Porous Substrate by Joint Sealants; 2022.
- H. ASTM C1311 - Standard Specification for Solvent Release Sealants; 2022.
- I. ASTM C1330 - Standard Specification for Cylindrical Sealant Backing for Use with Cold Liquid-Applied Sealants; 2018.
- J. ASTM D2240 - Standard Test Method for Rubber Property--Durometer Hardness; 2015 (Reapproved 2021).
- K. ASTM D695 - Standard Test Method for Compressive Properties of Rigid Plastics; 2015.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's technical datasheets for each product to be used; include the following:
  - 1. Physical characteristics, including movement capability, VOC content, hardness, cure time, and color availability.
  - 2. List of backing materials approved for use with the specific product.
  - 3. Substrates that product is known to satisfactorily adhere to and with which it is compatible.
  - 4. Substrates the product should not be used on.
  - 5. Substrates for which use of primer is required.
  - 6. Installation instructions, including precautions, limitations, and recommended backing materials and tools.
- C. Product Data for Accessory Products: Submit manufacturer's technical data sheet for each product to be used, including physical characteristics, installation instructions, and recommended tools.
- D. Color Cards for Selection: Where sealant color is not specified, submit manufacturer's color cards showing standard colors available for selection.
- E. Samples for Verification: Where custom sealant color is specified, obtain directions from Architect and submit at least two physical samples for verification of color of each required sealant.
- F. Executed warranty.

## **1.05 WARRANTY**

- A. See Section 017800 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for installed sealants and accessories that fail to achieve a watertight seal, exhibit loss of adhesion or cohesion, or do not cure. Complete forms in Owner's name and register with manufacturer.
- C. Extended Correction Period: Correct defective work within 5 period commencing on Date of Substantial Completion.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Nonsag Sealants:
  - 1. Bostik Inc: [www.bostik-us.com/#sle](http://www.bostik-us.com/#sle).
  - 2. Dow: [www.dow.com/#sle](http://www.dow.com/#sle).
  - 3. Hilti, Inc: [www.hilti.com/#sle](http://www.hilti.com/#sle).
  - 4. Momentive Performance Materials, Inc (formerly GE Silicones): [www.momentive.com/#sle](http://www.momentive.com/#sle).
  - 5. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
  - 6. Sika Corporation: [www.usa.sika.com/#sle](http://www.usa.sika.com/#sle).
  - 7. Tremco Commercial Sealants & Waterproofing: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
  - 8. W.R. Meadows, Inc: [www.wrmeadows.com/#sle](http://www.wrmeadows.com/#sle).
  - 9. Substitutions: See Section 016000 - Product Requirements.

### **2.02 JOINT SEALANT APPLICATIONS**

- A. Scope:
  - 1. Interior Joints: Do not seal interior joints unless specifically indicated to be sealed. Interior joints to be sealed include, but are not limited to, the following items.
    - a. Joints between door, window, and other frames and adjacent construction.
    - b. In sound-rated wall and ceiling assemblies, gaps at electrical outlets, wiring devices, piping, and other openings; between wall/ceiling and other construction; and other flanking sound paths.
      - 1) Exception: Such gaps and openings in gypsum board and plaster finished stud walls and suspended ceilings. See Section 092116 for additional information.
      - 2) Exception: Through-penetrations in sound-rated assemblies that are also fire-rated.
    - c. Other joints indicated below.
  - 2. Do not seal the following types of joints:
    - a. Joints indicated to be treated with manufactured expansion joint cover, or some other type of sealing device.
    - b. Joints where sealant is specified to be provided by manufacturer of product to be sealed.
    - c. Joints where installation of sealant is specified in another section.
    - d. Joints between suspended panel ceilings/grid and walls.
- B. Type \_\_\_\_ - Interior Joints: Use nonsag polyurethane sealant, unless otherwise indicated.
  - 1. Type \_\_\_\_ - In Sound-Rated Assemblies: Acrylic emulsion latex sealant.
- C. Sound-Rated Assemblies: Walls and ceilings identified as STC-rated, sound-rated, or acoustical.

### **2.03 JOINT SEALANTS - GENERAL**

### **2.04 NONSAG JOINT SEALANTS**

- A. Type NS-2 - Mildew-Resistant Silicone Sealant: ASTM C920, Grade NS, Uses M and A; single component, mildew resistant; not expected to withstand continuous water immersion or traffic.
  - 1. Color: White.
  - 2. Products:

- a. Sika Corporation; Sikasil GP: [www.usa.sika.com/#sle](http://www.usa.sika.com/#sle).
  - b. Substitutions: See Section 016000 - Product Requirements.
- B. Type NS-4 - Polyurethane Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
  - 1. Movement Capability: Plus and minus 25 percent, minimum.
  - 2. Color: To be selected by Architect from manufacturer's standard range.
  - 3. Service Temperature Range: Minus 40 to 180 degrees F (Minus 40 to 82 degrees C).
  - 4. Products:
    - a. Tremco Commercial Sealants & Waterproofing; Dymeric 240 FC: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.
- C. Type NS-6 - Epoxy Sealant: ASTM C881/C881M, Type I and III, Grade 3, Class B and C; two-component.
  - 1. Hardness Range: 65 to 75, Shore D, when tested in accordance with ASTM C661.
  - 2. Compressive Strength: 11,000 psi (76 MPa), when tested in accordance with ASTM D695.
  - 3. Color: To be selected by Architect from manufacturer's standard range.
  - 4. Service Temperature Range: 40 to 120 degrees F (4 to 49 degrees C).
  - 5. Products:
    - a. Pecora Corporation; DynaPoxy EP-1200 Two-Part Epoxy Security Sealant: [www.pecora.com/#sle](http://www.pecora.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.
- D. Type NS-7 - Acrylic Emulsion Latex: Water-based; ASTM C834, single component, nonstaining, nonbleeding, nonsagging; not intended for exterior use.
  - 1. Color: To be selected by Architect from manufacturer's standard range.
  - 2. Grade: ASTM C834; Grade 0 Degrees F (Minus 18 Degrees C).
  - 3. Products:
    - a. Tremco Commercial Sealants & Waterproofing; Tremstop Smoke and Sound: [www.tremcosealants.com/#sle](http://www.tremcosealants.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.

## **2.05 ACCESSORIES**

- A. Backer Rod: Cylindrical cellular foam rod with surface that sealant will not adhere to, compatible with specific sealant used, and recommended by backing and sealant manufacturers for specific application.
  - 1. Type for Joints Not Subject to Pedestrian or Vehicular Traffic: ASTM C1330; Type O - Open Cell Polyurethane.
  - 2. Type for Joints Subject to Pedestrian or Vehicular Traffic: ASTM C1330; Type B - Bi-Cellular Polyethylene.
  - 3. Open Cell: 40 to 50 percent larger in diameter than joint width.
  - 4. Closed Cell and Bi-Cellular: 25 to 33 percent larger in diameter than joint width.
- B. Backing Tape: Self-adhesive polyethylene tape with surface that sealant will not adhere to and recommended by tape and sealant manufacturers for specific application.
- C. Masking Tape: Self-adhesive, nonabsorbent, nonstaining, removable without adhesive residue, and compatible with surfaces adjacent to joints and sealants.
- D. Joint Cleaner: Noncorrosive and nonstaining type, type recommended by sealant manufacturer; compatible with joint forming materials.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that joints are ready to receive work.
- B. Verify that backing materials are compatible with sealants.

- C. Verify that backer rods are of the correct size.

### **3.02 PREPARATION**

- A. Remove loose materials and foreign matter that could impair adhesion of sealant.
- B. Clean joints, and prime as necessary, in accordance with manufacturer's instructions.
- C. Perform preparation in accordance with manufacturer's instructions and ASTM C1193.
- D. Mask elements and surfaces adjacent to joints from damage and disfigurement due to sealant work; be aware that sealant drips and smears may not be completely removable.
- E. Concrete Floor Joints That Will Be Exposed in Completed Work: Test joint filler in an inconspicuous area to verify that it does not stain or discolor slab.

### **3.03 INSTALLATION**

- A. Install this work in accordance with sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- B. Provide joint sealant installations complying with ASTM C1193.
- C. Install acoustical sealant application work in accordance with ASTM C919.
- D. Measure joint dimensions and size joint backers to achieve width-to-depth ratio, neck dimension, and surface bond area as recommended by manufacturer, except where specific dimensions are indicated.
- E. Install bond breaker backing tape where backer rod cannot be used.
- F. Install sealant free of air pockets, foreign embedded matter, ridges, and sags, and without getting sealant on adjacent surfaces.
- G. Do not install sealant when ambient temperature is outside manufacturer's recommended temperature range, or will be outside that range during the entire curing period, unless manufacturer's approval is obtained and instructions are followed.
- H. Nonsag Sealants: Tool surface concave, unless otherwise indicated; remove masking tape immediately after tooling sealant surface.

### **3.04 FIELD QUALITY CONTROL**

- A. See Section 014000 - Quality Requirements for additional requirements.
- B. Perform field quality control inspection/testing as specified in PART 1 under QUALITY ASSURANCE article.
- C. Remove and replace failed portions of sealants using same materials and procedures as indicated for original installation.

**END OF SECTION**

**SECTION 081113  
HOLLOW METAL DOORS AND FRAMES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Non-fire-rated hollow metal doors and frames.
- B. Hollow metal frames for wood doors.
- C. Thermally insulated hollow metal doors with frames.
- D. Hollow metal borrowed lites glazing frames.
- E. Accessories, including glazing, louvers, and matching panels.

**1.02 RELATED REQUIREMENTS**

- A. Section 087100 - Door Hardware.
- B. Section 099123 - Interior Painting: Field painting.

**1.03 ABBREVIATIONS AND ACRONYMS**

- A. ANSI: American National Standards Institute.
- B. HMMA: Hollow Metal Manufacturers Association.
- C. UL: Underwriters Laboratories.

**1.04 REFERENCE STANDARDS**

- A. ADA Standards - 2010 ADA Standards for Accessible Design; 2010.
- B. ANSI/SDI A250.4 - Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors; 2022.
- C. ANSI/SDI A250.8 - Specifications for Standard Steel Doors and Frames (SDI-100); 2017.
- D. ANSI/SDI A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames; 2020.
- E. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- F. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable; 2021a.
- G. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2018a.
- H. ASTM C143/C143M - Standard Test Method for Slump of Hydraulic-Cement Concrete; 2020.
- I. ASTM C476 - Standard Specification for Grout for Masonry; 2022.
- J. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023.
- K. BHMA A156.115 - Hardware Preparation in Steel Doors and Steel Frames; 2016.
- L. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2017.
- M. ITS (DIR) - Directory of Listed Products; Current Edition.
- N. NAAMM HMMA 830 - Hardware Selection for Hollow Metal Doors and Frames; 2002.
- O. NAAMM HMMA 831 - Hardware Locations for Hollow Metal Doors and Frames; 2011.
- P. NAAMM HMMA 840 - Guide Specifications For Receipt, Storage and Installation of Hollow Metal Doors and Frames; 2017.

- Q. NAAMM HMMA 861 - Guide Specifications for Commercial Hollow Metal Doors and Frames; 2014.
- R. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2022.
- S. NFPA 252 - Standard Methods of Fire Tests of Door Assemblies; 2022.
- T. SDI 117 - Manufacturing Tolerances for Standard Steel Doors and Frames; 2019.
- U. UL (DIR) - Online Certifications Directory; Current Edition.
- V. UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies; Current Edition, Including All Revisions.

## **1.05 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Materials and details of design and construction, hardware locations, reinforcement type and locations, anchorage and fastening methods, and finishes; and one copy of referenced standards/guidelines.
- C. Shop Drawings: Details of each opening, showing elevations, glazing, frame profiles, and any indicated finish requirements.
- D. Manufacturer's Qualification Statement.

## **1.06 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years documented experience.
- B. Maintain at project site copies of reference standards relating to installation of products specified.

## **1.07 DELIVERY, STORAGE, AND HANDLING**

- A. Comply with NAAMM HMMA 840 or ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
- B. Protect with resilient packaging; avoid humidity build-up under coverings; prevent corrosion and adverse effects on factory applied painted finish.

# **PART 2 PRODUCTS**

## **2.01 MANUFACTURERS**

- A. Hollow Metal Doors and Frames:
  - 1. Ceco Door, an Assa Abloy Group company: [www.assaabloydss.com/#sle](http://www.assaabloydss.com/#sle).
  - 2. Curries, an Assa Abloy Group company: [www.assaabloydss.com/#sle](http://www.assaabloydss.com/#sle).
  - 3. Republic Doors, an Allegion brand: [www.republicdoor.com/#sle](http://www.republicdoor.com/#sle).
  - 4. Steelcraft, an Allegion brand: [www.allegion.com/#sle](http://www.allegion.com/#sle).
  - 5. Substitutions: See Section 016000 - Product Requirements.

## **2.02 PERFORMANCE REQUIREMENTS**

- A. Requirements for Hollow Metal Doors and Frames:
  - 1. Steel Sheet: Comply with one or more of the following requirements; galvanized steel complying with ASTM A653/A653M, cold-rolled steel complying with ASTM A1008/A1008M, or hot-rolled pickled and oiled (HRPO) steel complying with ASTM A1011/A1011M, commercial steel (CS) Type B, for each.
  - 2. Accessibility: Comply with ICC A117.1 and ADA Standards.
  - 3. Exterior Door Top Closures: Flush end closure channel, with top and door faces aligned.
  - 4. Door Edge Profile: Manufacturers standard for application indicated.
  - 5. Typical Door Face Sheets: Flush.
  - 6. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings. Style: Manufacturer's standard.

7. Hardware Preparations, Selections and Locations: Comply with NAAMM HMMA 830 and NAAMM HMMA 831 or BHMA A156.115 and ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
  8. Zinc Coating for Typical Interior and/or Exterior Locations: Provide metal components zinc-coated (galvanized) and/or zinc-iron alloy-coated (galvannealed) by the hot-dip process in accordance with ASTM A653/A653M, with manufacturer's standard coating thickness, unless noted otherwise for specific hollow metal doors and frames.
    - a. Based on SDI Standards: Provide at least A40/ZF120 (galvannealed) when necessary, coating not required for typical interior door applications, and at least A60/ZF180 (galvannealed) for corrosive locations.
- B. Combined Requirements: If a particular door and frame unit is indicated to comply with more than one type of requirement, comply with the specified requirements for each type; for instance, an exterior door that is also indicated as being sound-rated must comply with the requirements specified for exterior doors and for sound-rated doors; where two requirements conflict, comply with the most stringent.

### **2.03 HOLLOW METAL DOORS**

- A. Door Finish: Factory primed and field finished.
- B. Exterior Doors: Thermally insulated.
1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
    - a. Level 1 - Standard-duty.
    - b. Physical Performance Level C, 250,000 cycles; in accordance with ANSI/SDI A250.4.
    - c. Model 1 - Full Flush.
    - d. Door Face Metal Thickness: 20 gauge, 0.032 inch (0.8 mm), minimum.
  2. Door Core Material: Polyisocyanurate, 2 lbs/cu ft minimum density.
    - a. Foam Plastic Insulation: Manufacturer's standard board insulation with maximum flame spread index (FSI) of 75, and maximum smoke developed index (SDI) of 450 in accordance with ASTM E84, and completely enclosed within interior of door.
  3. Door Thickness: 1-3/4 inches (44.5 mm), nominal.
  4. Weatherstripping: Refer to Section 087100.
- C. Interior Doors, Non-Fire-Rated:
1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
    - a. Level 1 - Standard-duty.
    - b. Physical Performance Level C, 250,000 cycles; in accordance with ANSI/SDI A250.4.
    - c. Model 1 - Full Flush.
    - d. Door Face Metal Thickness: 20 gauge, 0.032 inch (0.8 mm), minimum.
  2. Door Thickness: 1-3/4 inches (44.5 mm), nominal.

### **2.04 HOLLOW METAL FRAMES**

- A. Comply with standards and/or custom guidelines as indicated for corresponding door in accordance with applicable door frame requirements.
- B. Frame Finish: Same as hollow metal door.
- C. Exterior Door Frames: Full profile/continuously welded type.
1. Galvanizing: Components hot-dipped zinc-iron alloy-coated (galvannealed) in accordance with ASTM A653/A653M, with A40/ZF120 coating.
  2. Frame Metal Thickness: 18 gauge, 0.042 inch (1.0 mm), minimum.
  3. Weatherstripping: Separate, see Section 087100.
- D. Interior Door Frames, Non-Fire Rated: Full profile/continuously welded type.
1. Frame Metal Thickness: 18 gauge, 0.042 inch (1.0 mm), minimum.
- E. Frames for Wood Doors: Comply with frame requirements in accordance with corresponding door.
- F. Transom Bars: Fixed, of profile same as jamb and head.



- G. Provide mortar guard boxes for hardware cut-outs in frames to be installed in masonry or to be grouted.
- H. Frames in Masonry Walls: Size to suit masonry coursing with head member 4 inches (102 mm) high to fill opening without cutting masonry units.

## **2.05 FINISHES**

- A. Primer: Rust-inhibiting, complying with ANSI/SDI A250.10, door manufacturer's standard.

## **2.06 ACCESSORIES**

- A. Glazing: As specified in Section 088000, factory installed.
- B. Removable Stops: Formed sheet steel, shape as indicated on drawings, mitered or butted corners; prepared for countersink style tamper proof screws.
- C. Silencers: Resilient rubber, fitted into drilled hole; provide three on strike side of single door, three on center mullion of pairs, and two on head of pairs without center mullions.
- D. Temporary Frame Spreaders: Provide for factory- or shop-assembled frames.

# **PART 3 EXECUTION**

## **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Verify that finished walls are in plane to ensure proper door alignment.

## **3.02 PREPARATION**

## **3.03 INSTALLATION**

- A. Install doors and frames in accordance with manufacturer's instructions and related requirements of specified door and frame standards or custom guidelines indicated.
- B. Install fire rated units in accordance with NFPA 80.
- C. Coordinate frame anchor placement with wall construction.
- D. Install door hardware as specified in Section 087100.
- E. Comply with glazing installation requirements of Section 088000.
- F. Coordinate installation of electrical connections to electrical hardware items.
- G. Touch up damaged factory finishes.

## **3.04 TOLERANCES**

- A. Clearances Between Door and Frame: Comply with related requirements of specified frame standards or custom guidelines indicated in accordance with SDI 117 or NAAMM HMMA 861.
- B. Maximum Diagonal Distortion: 1/16 inch (1.6 mm) measured with straight edge, corner to corner.

## **3.05 ADJUSTING**

- A. Adjust for smooth and balanced door movement.

**END OF SECTION**

**SECTION 081416  
FLUSH WOOD DOORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Flush wood doors; flush and flush glazed configuration; non-rated.

**1.02 RELATED REQUIREMENTS**

- A. Section 081113 - Hollow Metal Doors and Frames.
- B. Section 087100 - Door Hardware.
- C. Section 088000 - Glazing.
- D. Section 099300 - Staining and Transparent Finishing: Field finishing of doors.

**1.03 REFERENCE STANDARDS**

- A. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards, 2nd Edition; 2014, with Errata (2016).
- B. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards; 2021, with Errata.
- C. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2022.
- D. NFPA 105 - Standard for Smoke Door Assemblies and Other Opening Protectives; 2022.
- E. UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies; Current Edition, Including All Revisions.
- F. UL 1784 - Standard for Air Leakage Tests of Door Assemblies; Current Edition, Including All Revisions.
- G. WDMA I.S. 1A - Interior Architectural Wood Flush Doors; 2021, with Errata (2022).

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Indicate door core materials and construction; veneer species, type and characteristics.
- C. Shop Drawings: Show doors and frames, elevations, sizes, types, swings, undercuts, beveling, blocking for hardware, factory machining, factory finishing, cutouts for glazing and other details.
- D. Samples: Submit two samples of door veneer, 12 by 12 inches (\_\_\_ by \_\_\_ mm) in size illustrating wood grain, stain color, and sheen.
- E. Warranty, executed in Owner's name.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section, with not less than three years of documented experience.

**1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Package, deliver and store doors in accordance with specified quality standard.
- B. Accept doors on site in manufacturer's packaging, and inspect for damage.
- C. Protect doors with resilient packaging sealed with heat shrunk plastic; do not store in damp or wet areas or areas where sunlight might bleach veneer; seal top and bottom edges with tinted sealer if stored more than one week, and break seal on site to permit ventilation.

**1.07 WARRANTY**

- A. See Section 017800 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide manufacturer's warranty on interior doors for the life of the installation. Complete forms in Owner's name and register with manufacturer.

1. Include coverage for delamination of veneer, warping beyond specified installation tolerances, defective materials, and telegraphing core construction.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Wood Veneer Faced Doors:
  1. Masonite Architectural; Aspiro Select Wood Veneer Doors: [www.architectural.masonite.com/#sle](http://www.architectural.masonite.com/#sle).
  2. VT Industries, Inc; \_\_\_\_: [www.vtindustries.com/#sle](http://www.vtindustries.com/#sle).
  3. Substitutions: See Section 016000 - Product Requirements.

### **2.02 DOORS AND PANELS**

- A. Doors: See drawings for locations and additional requirements.
  1. Quality Standard: Custom Grade, Heavy Duty performance, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
  2. Wood Veneer Faced Doors: 5-ply unless otherwise indicated.
- B. Interior Doors: 1-3/4 inches (44 mm) thick unless otherwise indicated; flush construction.
  1. Provide solid core doors at each location.
  2. Fire Rated Doors: Tested to ratings indicated on drawings in accordance with UL 10C - Positive Pressure; Underwriters Laboratories Inc (UL) or Intertek/Warnock Hersey (WHI) labeled without any visible seals when door is open.
  3. Smoke and Draft Control Doors (Indicated as "S" on Drawings): In addition to required fire rating, provide door assemblies tested in accordance with UL 1784 with maximum air leakage of 3.0 cfm per sq ft (0.01524 cu m/s/sq m) of door opening at 0.10 inch wg (24.9 Pa) pressure at both ambient and elevated temperatures for "S" label; if necessary, provide additional gasketing or edge sealing.
  4. Wood veneer facing for field transparent finish.

### **2.03 DOOR AND PANEL CORES**

- A. Non-Rated Solid Core and 20 Minute Rated Doors: Type particleboard core (PC), plies and faces as indicated.

### **2.04 DOOR FACINGS**

- A. Veneer Facing for Transparent Finish: Red oak, veneer grade in accordance with quality standard indicated, plain sliced (flat cut), with book match between leaves of veneer, running match of spliced veneer leaves assembled on door or panel face.
  1. Vertical Edges: Same species as face veneer.

### **2.05 DOOR CONSTRUCTION**

- A. Fabricate doors in accordance with door quality standard specified.
- B. Cores Constructed with stiles and rails:
- C. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- D. Factory fit doors for frame opening dimensions identified on shop drawings, with edge clearances in accordance with specified quality standard.
- E. Provide edge clearances in accordance with the quality standard specified.

### **2.06 FINISHES - WOOD VENEER DOORS**

- A. Finish work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), Section 5 - Finishing for grade specified and as follows:
  1. Transparent:
    - a. System - 11, Polyurethane, Catalyzed.
    - b. Stain: As selected by Architect.
    - c. Sheen: Satin.

- B. Factory finish doors in accordance with approved sample.
- C. Seal door top edge with color sealer to match door facing.

## **2.07 ACCESSORIES**

- A. Hollow Metal Door Frames: See Section 081113.
- B. Glazing: See Section 088000.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Do not install doors in frame openings that are not plumb or are out-of-tolerance for size or alignment.

### **3.02 INSTALLATION**

- A. Install doors in accordance with manufacturer's instructions and specified quality standard.
  - 1. Install fire-rated doors in accordance with NFPA 80 requirements.
  - 2. Install smoke and draft control doors in accordance with NFPA 105 requirements.
- B. Factory-Finished Doors: Do not field cut or trim; if fit or clearance is not correct, replace door.
- C. Use machine tools to cut or drill for hardware.
- D. Coordinate installation of doors with installation of frames and hardware.

### **3.03 TOLERANCES**

- A. Comply with specified quality standard for fit and clearance tolerances.
- B. Comply with specified quality standard for telegraphing, warp, and squareness.

### **3.04 ADJUSTING**

- A. Adjust doors for smooth and balanced door movement.
- B. Adjust closers for full closure.

### **3.05 SCHEDULE**

- A. See Door and Frame Schedule appended to this section.

**END OF SECTION**

SECTION 08 71 00 – DOOR HARDWARE

PART 1 - GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

A. Section includes:

- 1. Mechanical and electrified door hardware for:
  - a. Swinging doors.
- 2. The intent of the hardware specification is to specify the hardware for interior and exterior doors, and to establish a type, continuity, and standard of quality. However, it is the door hardware supplier's responsibility to thoroughly review existing conditions, schedules, specifications, drawings, and other Contract Documents to verify the suitability of the hardware specified.

B. Exclusions: Unless specifically listed in hardware sets, hardware is not specified in this section for:

- 1. Windows
- 2. Cabinets (casework), including locks in cabinets
- 3. Signage
- 4. Toilet accessories
- 5. Overhead doors

C. Related Sections:

- 1. Division 01 Section "Alternates" for alternates affecting this section.
- 2. Division 06 Section "Rough Carpentry"
- 3. Division 06 Section "Finish Carpentry: Installation of Finish Hardware"
- 4. Division 07 Section "Joint Sealants" for sealant requirements applicable to threshold installation specified in this section.
- 5. Division 08 Section "Hollow Metal Frames"
- 6. Division 08 Section "Flush Wood Doors"

1.03 REFERENCES

A. UL - Underwriters Laboratories

- 1. UL 10B - Fire Test of Door Assemblies
- 2. UL 10C - Positive Pressure Test of Fire Door Assemblies
- 3. UL 1784 - Air Leakage Tests of Door Assemblies

B. DHI - Door and Hardware Institute

1. Sequence and Format for the Hardware Schedule
2. Recommended Locations for Builders Hardware
3. Key Systems and Nomenclature

C. ANSI - American National Standards Institute

1. ANSI/BHMA A156.1 - A156.29, and ANSI/BHMA A156.31 - Standards for Hardware and Specialties

1.04 SUBMITTALS

A. General:

1. Submit in accordance with Conditions of Contract and Division 01 requirements.
2. Highlight, encircle, or otherwise specifically identify on submittals deviations from Contract Documents, issues of incompatibility or other issues which may detrimentally affect the Work.
3. Prior to forwarding submittal, comply with procedures for verifying existing door and frame compatibility for new hardware, as specified in PART 3, "EXAMINATION" article, herein.

B. Action Submittals:

1. Product Data: Technical product data for each item of door hardware, installation instructions, maintenance of operating parts and finish, and other information necessary to show compliance with requirements.
2. Samples for Verification: If requested by Architect, submit production sample of requested door hardware unit in finish indicated, and tagged with full description for coordination with schedule.
  - a. Samples will be returned to supplier. Units that are acceptable to Architect may, after final check of operations, be incorporated into Work, within limitations of key coordination requirements.
3. Door Hardware Schedule: Submit schedule with hardware sets in vertical format as illustrated by Sequence of Format for the Hardware Schedule as published by the Door and Hardware Institute. Indicate complete designations of each item required for each door or opening, include:
  - a. Door Index; include door number, heading number, and Architects hardware set number.
  - b. Opening Lock Function Spreadsheet: List locking device and function for each opening.
  - c. Quantity, type, style, function, size, and finish of each hardware item.
  - d. Name and manufacturer of each item.
  - e. Fastenings and other pertinent information.
  - f. Location of each hardware set cross-referenced to indications on Drawings.
  - g. Explanation of all abbreviations, symbols, and codes contained in schedule.
  - h. Mounting locations for hardware.
  - i. Door and frame sizes and materials.
  - j. Name and phone number for local manufacturer's representative for each product.
4. Key Schedule:

## Grand Rapids Public Schools (GRPS) – Union High School Health Center

- a. Refer to Part 2 – Section 2.06 for Keying Requirements.

### C. Informational Submittals:

1. Qualification Data: For Supplier, Installer and Architectural Hardware Consultant.
2. Product data for electrified door hardware:
  - a. Certify that door hardware approved for use on types and sizes of labeled fire-rated doors complies with listed fire-rated door assemblies.
3. Warranty: Special warranty specified in this Section.

### D. Closeout Submittals:

1. Operations and Maintenance Data: Provide in accordance with Division 01 and include:
  - a. Complete information on care, maintenance, and adjustment; data on repair and replacement parts, and information on preservation of finishes.
  - b. Catalog pages for each product.
  - c. Factory order acknowledgement numbers (for warranty and service)
  - d. Name, address, and phone number of local representative for each manufacturer.
  - e. Parts list for each product.
  - f. Final approved hardware schedule, edited to reflect conditions as-installed.
  - g. Final keying schedule
  - h. Copies of floor plans with keying nomenclature
  - i. Copy of warranties including appropriate reference numbers for manufacturers to identify project.

## 1.05 QUALITY ASSURANCE

- A. Supplier Qualifications and Responsibilities: Recognized architectural hardware supplier with record of successful in-service performance for supplying door hardware similar in quantity, type, and quality to that indicated for this Project and that provides certified Architectural Hardware Consultant (AHC) or Door Hardware Consultant (DHC) available to Owner, Architect, and Contractor, at reasonable times during the Work for consultation.
  1. Warehousing Facilities: In Project's vicinity.
  2. Scheduling Responsibility: Preparation of door hardware and keying schedules.
- B. Architectural Hardware Consultant Qualifications: Person who is experienced in providing consulting services for door hardware installations that are comparable in material, design, and extent to that indicated for this Project and meets these requirements:
  1. For door hardware, DHI-certified, Architectural Hardware Consultant (AHC) or Door Hardware Consultant (DHC).
  2. Can provide installation and technical data to Architect and other related subcontractors.
  3. Can inspect and verify components are in working order upon completion of installation.
- C. Single Source Responsibility: Obtain each type of door hardware from single manufacturer.
- D. Fire-Rated Door Openings: Provide door hardware for fire-rated openings that complies with NFPA 80 and requirements of authorities having jurisdiction. Provide only items of door hardware that are listed products tested by Underwriters Laboratories, Intertek Testing Services, or other testing and inspecting organizations acceptable to authorities having jurisdiction for use on types and sizes of doors indicated, based on testing at positive

## Grand Rapids Public Schools (GRPS) – Union High School Health Center

pressure and according to NFPA 252 or UL 10C and in compliance with requirements of fire-rated door and door frame labels.

E. Accessibility Requirements: For door hardware on doors in an accessible route, comply with governing accessibility regulations cited in “REFERENCES” article, herein.

F. Keying Conference

1. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including:
  - a. Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
  - b. Preliminary key system schematic diagram.
  - c. Requirements for key control system.
  - d. Requirements for access control.
  - e. Address for delivery of keys.

G. Pre-installation Conference

1. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
2. Inspect and discuss preparatory work performed by other trades.
3. Review required testing, inspecting, and certifying procedures.

H. Coordination Conferences:

1. Installation Coordination Conference: Prior to hardware installation, schedule and hold meeting to review questions or concerns related to proper installation and adjustment of door hardware.

### 1.06 DELIVERY, STORAGE, AND HANDLING

A. Inventory door hardware on receipt and provide secure lock-up for hardware delivered to Project site.

B. Tag each item or package separately with identification coordinated with final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package.

1. Deliver each article of hardware in manufacturer's original packaging.

C. Project Conditions:

1. Maintain manufacturer-recommended environmental conditions throughout storage and installation periods.
2. Provide secure lock-up for door hardware delivered to Project. Control handling and installation of hardware items so that completion of Work will not be delayed by hardware losses both before and after installation.

D. Protection and Damage:

1. Promptly replace products damaged during shipping.



## Grand Rapids Public Schools (GRPS) – Union High School Health Center

2. Handle hardware in manner to avoid damage, marring, or scratching. Correct, replace or repair products damaged during Work.
3. Protect products against malfunction due to paint, solvent, cleanser, or any chemical agent.

### 1.07 COORDINATION

- A. Coordinate layout and installation of floor-recessed door hardware with floor construction. Cast anchoring inserts into concrete.
- B. Installation Templates: Distribute for doors, frames, and other work specified to be factory or shop prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
- C. Security: Coordinate installation of door hardware and keying with Owner's security consultant.

### 1.08 WARRANTY

- A. Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.
  1. Warranty Period: Beginning from date of Substantial Completion, for durations indicated.
    - a. Closers:
      - 1) Mechanical: 10 years.
    - b. Locksets:
      - 1) Mechanical: 3 years.
    - c. Key Blanks: Lifetime
  2. Warranty does not cover damage or faulty operation due to improper installation, improper use or abuse.

### 1.09 MAINTENANCE

- A. Maintenance Tools: Furnish complete set of special tools required for maintenance and adjustment of hardware, including changing of cylinders.

## PART 2 - PRODUCTS

### 2.01 MANUFACTURERS

- A. The Owner requires use of certain products for their unique characteristics and project suitability to insure continuity of existing and future performance and maintenance standards. After investigating available product offerings, the Awarding Authority has elected to prepare proprietary specifications. These products are specified with the notation: "No Substitute."

## Grand Rapids Public Schools (GRPS) – Union High School Health Center

1. Where “No Substitute” is noted, submittals and substitution requests for other products will not be considered.
- B. Approval of manufacturers and/or products other than those listed as “Scheduled Manufacturer” or “Acceptable Manufacturers” in the individual article for the product category shall be in accordance with QUALITY ASSURANCE article, herein.
- C. Approval of products from manufacturers indicated in “Acceptable Manufacturers” is contingent upon those products providing all functions and features and meeting all requirements of scheduled manufacturer’s product.
- D. Where specified hardware is not adaptable to finished shape or size of members requiring hardware, furnish suitable types having same operation and quality as type specified, subject to Architect's approval.

### 2.02 MATERIALS

#### A. Fasteners

1. Provide hardware manufactured to conform to published templates, generally prepared for machine screw installation.
  2. Furnish screws for installation with each hardware item. Finish exposed (exposed under any condition) screws to match hardware finish, or, if exposed in surfaces of other work, to match finish of this other work including prepared for paint surfaces to receive painted finish.
  3. Provide concealed fasteners for hardware units exposed when door is closed except when no standard units of type specified are available with concealed fasteners. Do not use thru-bolts for installation where bolt head or nut on opposite face is exposed in other work unless thru-bolts are required to fasten hardware securely. Review door specification and advise Architect if thru-bolts are required.
  4. Install hardware with fasteners provided by hardware manufacturer.
- B. Provide screws, bolts, expansion shields, drop plates and other devices necessary for hardware installation.
1. Where fasteners are exposed to view: Finish to match adjacent door hardware material.

### 2.03 HINGES

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Ives 5BB Series.
2. Acceptable Manufacturers and Products: Hager BB Series, McKinney TA/T4A Series, Stanley FBB Series.

#### B. Requirements:

1. Provide hinges conforming to ANSI/BHMA A156.1.
2. 1-3/4 inch (44 mm) thick doors, up to and including 36 inches (914 mm) wide:
  - a. Exterior: Standard weight, bronze or stainless steel, 4-1/2 inches (114 mm) high
  - b. Interior: Standard weight, steel, 4-1/2 inches (114 mm) high

3. 1-3/4 inch (44 mm) thick doors over 36 inches (914 mm) wide:
  - a. Exterior: Heavy weight, bronze/stainless steel, 5 inches (127 mm) high
  - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
4. 2 inches or thicker doors:
  - a. Exterior: Heavy weight, bronze or stainless steel, 5 inches (127 mm) high
  - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
5. Provide three hinges per door leaf for doors 90 inches (2286 mm) or less in height, and one additional hinge for each 30 inches (762 mm) of additional door height.
6. Where new hinges are specified for existing doors or existing frames, provide new hinges of identical size to hinge preparation present in existing door or existing frame.
7. Hinge Pins: Except as otherwise indicated, provide hinge pins as follows:
  - a. Steel Hinges: Steel pins
  - b. Non-Ferrous Hinges: Stainless steel pins
  - c. Out-Swinging Exterior Doors: Non-removable pins
  - d. Out-Swinging Interior Lockable Doors: Non-removable pins
  - e. Interior Non-lockable Doors: Non-rising pins
8. Width of hinges: 4-1/2 inches (114 mm) at 1-3/4 inch (44 mm) thick doors, and 5 inches (127 mm) at 2 inches (51 mm) or thicker doors. Adjust hinge width as required for door, frame, and wall conditions to allow proper degree of opening.

## 2.04 MORTISE LOCKS

### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Schlage L9000 Series.
2. Acceptable Manufacturers and Products: Best 45H Series, Sargent 8200 Series.

### B. Requirements:

1. Provide mortise locks conforming to ANSI/BHMA A156.13 Series 1000, Grade 1, and UL Listed for 3 hour fire doors.
2. Indicators: Where specified, provide indicator window measuring a minimum 2 inch x 1/2 inch with 180 degree visibility. Provide messages color-coded with full text and/or symbols, as scheduled, for easy visibility.
  - a. Inside Security Indicator: Provide indicator above cylinder or thumbturn for visibility during lockdown that identifies the outside trim as locked/unlocked status of the door.
3. Provide locks manufactured from heavy gauge steel, containing components of steel with a zinc dichromate plating for corrosion resistance.
4. Provide lock case that is multi-function and field reversible for handing without opening case. Cylinders: Refer to "KEYING" article, herein.
5. Provide locks with standard 2-3/4 inches (70 mm) backset with full 3/4 inch (19 mm) throw stainless steel mechanical anti-friction latchbolt. Provide deadbolt with full 1 inch (25 mm) throw, constructed of stainless steel.
6. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
7. Provide electrified options as scheduled in the hardware sets. Where scheduled, provide switches and sensors integrated into the locks and latches.

## Grand Rapids Public Schools (GRPS) – Union High School Health Center

8. Lever Trim: Solid brass, bronze, or stainless steel, cast or forged in design specified, with wrought roses and external lever spring cages. Provide thru-bolted levers with 2-piece spindles.
  - a. Lever Design: Schlage 06N.
  - b. Tactile Warning (Knurling): Where required by authority having jurisdiction. Provide on levers on exterior (secure side) of doors serving rooms considered to be hazardous.

### 2.05 CYLINDERS

#### A. Manufacturers:

1. Scheduled Manufacturer: Schlage.
2. Acceptable Manufacturers and Products: No Substitution.

#### B. Requirements:

1. Provide interchangeable cylinders to match Owner's existing key system, compliant with ANSI/BHMA A156.5; latest revision; cylinder face finished to match lockset, manufacturer's series as indicated. Refer to "KEYING" article, herein.
2. Provide the following keyway: Schlage SFIC cores shall be furnished by GRPS.

#### C. Construction Keying:

1. Replaceable Construction Cores.
  - a. Provide temporary construction cores replaceable by permanent cores, furnished in accordance with the following requirements.
    - 1) 3 construction control keys
    - 2) 12 construction change (day) keys.
  - b. Owner or Owner's Representative will replace temporary construction cores with permanent cores.

### 2.06 KEYING

- #### A. Provided by GRPS.

### 2.07 DOOR CLOSERS

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: LCN 4040XP Series.
2. Acceptable Manufacturers and Products: Sargent 281 Series.

#### B. Requirements:

1. Provide door closers conforming to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. ISO 9000 certify closers. Stamp units with date of manufacture code.
2. Provide door closers with fully hydraulic, full rack and pinion action with high strength cast iron cylinder, and full complement bearings at shaft.

3. Cylinder Body: 1-1/2 inch (38 mm) diameter with 5/8 inch (16 mm) diameter double heat-treated pinion journal.
4. Hydraulic Fluid: Fireproof, passing requirements of UL10C, and requiring no seasonal closer adjustment for temperatures ranging from 120 degrees F to -30 degrees F.
5. Spring Power: Continuously adjustable over full range of closer sizes, and providing reduced opening force as required by accessibility codes and standards.
6. Hydraulic Regulation: By tamper-proof, non-critical valves, with separate adjustment for latch speed, general speed, and backcheck.
7. Provide closers with solid forged steel main arms and factory assembled heavy-duty forged forearms for parallel arm closers.
8. Pressure Relief Valve (PRV) Technology: Not permitted.
9. Finish for Closer Cylinders, Arms, Adapter Plates, and Metal Covers: Powder coating finish which has been certified to exceed 100 hours salt spray testing as described in ANSI Standard A156.4 and ASTM B117, or has special rust inhibitor (SRI).
10. Provide special templates, drop plates, mounting brackets, or adapters for arms as required for details, overhead stops, and other door hardware items interfering with closer mounting.
11. **Provide through-bolts for wood door closers.**

## 2.08 PROTECTION PLATES

### A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Trimco, Rockwood.

### B. Requirements:

1. Provide kick plates, mop plates, and armor plates minimum of 0.050 inch (1 mm) thick, beveled four edges as scheduled. Furnish with sheet metal or wood screws, finished to match plates.
2. Sizes of plates:
  - a. Kick Plates: 10 inches (254 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs

## 2.09 OVERHEAD STOPS AND OVERHEAD STOP/HOLDERS

### A. Manufacturers:

1. Scheduled Manufacturers: Glynn-Johnson.
2. Acceptable Manufacturers: Rixson.

### B. Requirements:

1. Provide heavy duty concealed mounted overhead stop or holder as specified for exterior and interior vestibule single acting doors.
2. Provide heavy duty concealed mounted overhead stop or holder as specified for double acting doors.
3. Provide heavy or medium duty and concealed or surface mounted overhead stop or holder for interior doors as specified. Provide medium duty surface mounted overhead stop for interior doors and at any door that swings more than 140 degrees before striking

wall, open against equipment, casework, sidelights, and where conditions do not allow wall stop or floor stop presents tripping hazard.

4. Where overhead holders are specified provide friction type at doors without closer and positive type at doors with closer.

## 2.10 DOOR STOPS AND HOLDERS

### A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Trimco, Rockwood.

### B. Provide door stops at each door leaf:

1. Provide wall stops wherever possible. Provide convex type where mortise type locks are used and concave type where cylindrical type locks are used.
2. Where a wall stop cannot be used, provide universal floor stops for low or high rise options.
3. Where wall or floor stop cannot be used, provide medium duty surface mounted overhead stop.

## 2.11 THRESHOLDS, SEALS, DOOR SWEEPS, AUTOMATIC DOOR BOTTOMS, AND GASKETING

### A. Manufacturers:

1. Scheduled Manufacturer: Zero International.
2. Acceptable Manufacturers: National Guard, Reese, Pemko

### B. Requirements:

1. Provide thresholds, weather-stripping (including door sweeps, seals, and astragals) and gasketing systems (including smoke, sound, and light) as specified and per architectural details. Match finish of other items.
2. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that meets requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105.
3. Provide door sweeps, seals, astragals, and auto door bottoms only of type where resilient or flexible seal strip is easily replaceable and readily available.

## 2.12 SILENCERS

### A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Trimco, Rockwood.

### B. Requirements:

1. Provide "push-in" type silencers for hollow metal or wood frames.
2. Provide one silencer per 30 inches (762 mm) of height on each single frame, and two for each pair frame.
3. Omit where gasketing is specified.

## 2.13 FINISHES

- A. Finish: Generally, satin chromium BHMA 626/652 (US26D). Provide finish for each item as indicated in sets.

## PART 3 - EXECUTION

### 3.01 EXAMINATION

- A. Prior to installation of hardware, examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 INSTALLATION

- A. Mount door hardware units at heights to comply with the following, unless otherwise indicated or required to comply with governing regulations.
  - 1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
  - 2. Custom Steel Doors and Frames: HMMA 831.
  - 3. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."
- B. Install each hardware item in compliance with manufacturer's instructions and recommendations, using only fasteners provided by manufacturer.
- C. Do not install surface mounted items until finishes have been completed on substrate. Protect all installed hardware during painting.
- D. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate as necessary for proper installation and operation.
- E. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
- F. Install operating parts so they move freely and smoothly without binding, sticking, or excessive clearance.
- G. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than quantity recommended by manufacturer for application indicated or one hinge for every 30 inches (750 mm) of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.
- H. Lock Cylinders: Install construction cores to secure building and areas during construction period.
  - 1. Owner shall replace construction cores with permanent cores as indicated in keying section.

## Grand Rapids Public Schools (GRPS) – Union High School Health Center

- I. Key Control System: Tag keys and place them on markers and hooks in key control system cabinet, as determined by final keying schedule.
- J. Door Closers: Mount closers on room side of corridor doors, inside of exterior doors, and stair side of stairway doors from corridors. Mount closers so they are not visible in corridors, lobbies and other public spaces unless approved by Architect.
- K. Closer/Holders: Mount closer/holders on room side of corridor doors, inside of exterior doors, and stair side of stairway doors.
- L. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they may impede traffic or present tripping hazard.
- M. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.

### 3.03 FIELD QUALITY CONTROL

- A. Engage qualified manufacturer trained representative to perform inspections and to prepare inspection reports.
  - 1. Representative will inspect door hardware and state in each report whether installed work complies with or deviates from requirements, including whether door hardware is properly installed and adjusted.

### 3.04 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
  - 1. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.
- B. Occupancy Adjustment: Approximately three to six months after date of Substantial Completion, Installer's Architectural Hardware Consultant must examine and readjust each item of door hardware, including adjusting operating forces, as necessary to ensure function of doors and door hardware.

### 3.05 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items as necessary to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of Substantial Completion.



## Grand Rapids Public Schools (GRPS) – Union High School Health Center

### 3.06 DOOR HARDWARE SCHEDULE

A. Hardware items are referenced in the following hardware. Refer to the above-specifications for special features, options, cylinders/keying, and other requirements.

B. Hardware Sets:

#### Hardware Group No. 01

For use on Door #(s):

109                      111

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	PASSAGE SET	L9010 06N	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

#### Hardware Group No. 02

For use on Door #(s):

101                      107

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050BDC 06N 09-544	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

#### Hardware Group No. 03

For use on Door #(s):

108

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050BDC 06N 09-544	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	OH STOP	100S	630	GLY
3	EA	SILENCER	SR64	GRY	IVE

# Grand Rapids Public Schools (GRPS) – Union High School Health Center

## Hardware Group No. 04

For use on Door #(s):

T-1

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CORRIDOR LOCK W/OUTSIDE INDICATOR	L9456BDC 06N 09-544 OS-OCC	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA - PULL-SIDE	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS33(X)	626	IVE
1	EA	GASKETING	488S	BK	ZER

## Hardware Group No. 05

For use on Door #(s):

100B

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM SECURITY W/INSIDE INDICATOR	L9071BDC 06N IS-LOC	626	SCH
2	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	SURFACE CLOSER	4040XP SCUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

## Hardware Group No. 06

For use on Door #(s):

100A

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080BDC 06N	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA - PUSH-SIDE	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Grand Rapids Public Schools (GRPS) – Union High School Health Center

Hardware Group No. 07

For use on Door #(s):

110

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080BDC 06N	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	SURFACE CLOSER	4040XP SCUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Group No. 08

For use on Door #(s):

114

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080BDC 06N	626	SCH
1	EA	SFIC PERMANENT CORE	PROVIDED BY OWNER	626	SCH
1	EA	SURFACE CLOSER	4040XP SCUSH	689	LCN
3	EA	SILENCER	SR64	GRY	IVE

Hardware Group No. 09

For use on Door #(s):

102

Each to have:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
			HARDWARE BY DOOR MANUFACTURER		

**END OF SECTION 087100**

**SECTION 092116  
GYPSUM BOARD ASSEMBLIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Performance criteria for gypsum board assemblies.
- B. Metal stud wall framing.
- C. Acoustic insulation.
- D. Gypsum wallboard.
- E. Joint treatment and accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 061000 - Rough Carpentry: Building framing and sheathing.
- B. Section 061000 - Rough Carpentry: Wood blocking product and execution requirements.
- C. Section 079200 - Joint Sealants: Sealing acoustical gaps in construction other than gypsum board or plaster work.

**1.03 REFERENCE STANDARDS**

- A. AISI S220 - North American Standard for Cold-Formed Steel Nonstructural Framing; 2020.
- B. AISI S240 - North American Standard for Cold-Formed Steel Structural Framing; 2015, with Errata (2020).
- C. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- D. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- E. ASTM A1003/A1003M - Standard Specification for Steel Sheet, Carbon, Metallic- and Nonmetallic-Coated for Cold-Formed Framing Members; 2015.
- F. ASTM C475/C475M - Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board; 2017 (Reapproved 2022).
- G. ASTM C514 - Standard Specification for Nails for the Application of Gypsum Board; 2004 (Reapproved 2020).
- H. ASTM C557 - Standard Specification for Adhesives for Fastening Gypsum Wallboard to Wood Framing; 2003 (Reapproved 2017).
- I. ASTM C665 - Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing; 2017.
- J. ASTM C754 - Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products; 2020.
- K. ASTM C840 - Standard Specification for Application and Finishing of Gypsum Board; 2020.
- L. ASTM C954 - Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs from 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness; 2022.
- M. ASTM C1002 - Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs; 2022.
- N. ASTM C1047 - Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base; 2019.
- O. ASTM C1396/C1396M - Standard Specification for Gypsum Board; 2017.
- P. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber; 2021.

- Q. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023.
- R. ASTM E90 - Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements; 2009 (Reapproved 2016).
- S. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2022.
- T. ASTM E413 - Classification for Rating Sound Insulation; 2022.
- U. GA-216 - Application and Finishing of Gypsum Panel Products; 2021.
- V. GA-600 - Fire Resistance and Sound Control Design Manual; 2021.
- W. ICC (IBC) - International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- X. UL (FRD) - Fire Resistance Directory; Current Edition.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data:
  - 1. Provide manufacturer's data on partition head to structure connectors, showing compliance with requirements.
- C. Shop Drawings: Indicate special details associated with fireproofing and acoustic seals.

#### **1.05 DELIVERY, STORAGE, AND HANDLING**

- A. Store gypsum products and accessories indoors and keep above freezing. Elevate boards above floor, on nonwicking supports, in accordance with manufacturer's recommendations.

### **PART 2 PRODUCTS**

#### **2.01 GYPSUM BOARD ASSEMBLIES**

- A. Provide completed assemblies complying with ASTM C840 and GA-216.
- B. Interior Partitions, Indicated as Acoustic: Provide completed assemblies with the following characteristics:
  - 1. Acoustic Attenuation: STC of 50-54 calculated in accordance with ASTM E413, based on tests conducted in accordance with ASTM E90.
- C. Fire-Resistance-Rated Assemblies: Provide completed assemblies with the following characteristics:
  - 1. ICC IBC Item Numbers: Comply with applicable requirements of ICC IBC for the particular assembly.
  - 2. Gypsum Association File Numbers: Comply with requirements of GA-600 for the particular assembly.
  - 3. UL Assembly Numbers: Provide construction equivalent to that listed for the particular assembly in the current UL (FRD).

#### **2.02 METAL FRAMING MATERIALS**

- A. Steel Sheet: ASTM A1003/A1003M, subject to the ductility limitations indicated in AISI S240.
- B. Manufacturers - Metal Framing, Connectors, and Accessories:
  - 1. ClarkDietrich: [www.clarkdietrich.com/#sle](http://www.clarkdietrich.com/#sle).
  - 2. Jaimes Industries: [www.jaimesind.com/#sle](http://www.jaimesind.com/#sle).
  - 3. MarinoWARE: [www.marinoware.com/#sle](http://www.marinoware.com/#sle).
  - 4. Substitutions: See Section 016000 - Product Requirements.
- C. Nonstructural Framing System Components: AISI S220; galvanized sheet steel, of size and properties necessary to comply with ASTM C754 for the spacing indicated, with maximum deflection of wall framing of L/240 at 5 psf (L/240 at 240 Pa).
  - 1. Studs: C-shaped with knurled or embossed faces.

2. Runners: U shaped, sized to match studs.
- D. Partition Head to Structure Connections: Provide mechanical anchorage devices that accommodate deflection and prevent rotation of studs while maintaining structural performance of partition.
  1. Structural Performance: Maintain lateral load resistance and vertical movement capacity required by applicable code, when evaluated in accordance with AISI S100.
  2. Material: ASTM A653/A653M steel sheet, SS Grade 50/340, with G60/Z180 hot-dipped galvanized coating.
  3. Provide components UL-listed for use in UL-listed fire-resistance-rated head of partition joint systems indicated on drawings.
- E. Deflection and Firestop Track: Intumescent strip factory-applied to track flanges expands when exposed to heat or flames to provide a perimeter joint seal.
- F. Preformed Top Track Firestop Seal:
  1. Provide components UL-listed for use in UL-listed fire-resistance-rated head of partition joint systems indicated on drawings.
- G. Preformed Top of Wall Firestop Gasket:
  1. Provide components UL-listed for use in UL-listed fire-resistance-rated head of partition joint systems indicated on drawings.
- H. Non-structural Framing Accessories:
  1. Partial Height Wall Framing Support: Provides stud reinforcement and anchored connection to floor.
    - a. Materials: ASTM A36/A36M formed sheet steel support member with factory-welded ASTM A1003/A1003M steel plate base.
    - b. Height: 35-3/4 inches (908 mm) and 47-3/4 inches (1213 mm).
    - c. Products:
      - 1) ClarkDietrich; Pony Wall (PW): [www.clarkdietrich.com/#sle](http://www.clarkdietrich.com/#sle).
      - 2) Substitutions: See Section 016000 - Product Requirements.

## 2.03 BOARD MATERIALS

- A. Manufacturers - Gypsum-Based Board:
  1. American Gypsum Company: [www.americangypsum.com/#sle](http://www.americangypsum.com/#sle).
  2. CertainTeed Corporation: [www.certainteed.com/#sle](http://www.certainteed.com/#sle).
  3. Georgia-Pacific Gypsum: [www.gpgypsum.com/#sle](http://www.gpgypsum.com/#sle).
  4. USG Corporation: [www.usg.com/#sle](http://www.usg.com/#sle).
  5. Substitutions: See Section 016000 - Product Requirements.
- B. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
  1. Application: Use for vertical surfaces and ceilings, unless otherwise indicated.
  2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  3. Thickness:
    - a. Vertical Surfaces: 5/8 inch (16 mm).
    - b. Multi-Layer Assemblies: Thicknesses as indicated on drawings.

## 2.04 GYPSUM BOARD ACCESSORIES

- A. Acoustic Insulation: ASTM C665; preformed mineral-fiber, friction fit type, unfaced; thickness as required for STC.
- B. Finishing Accessories: ASTM C1047, extruded aluminum alloy (6063 T5) or galvanized steel sheet ASTM A924/A924M G90, unless noted otherwise.
  1. Types: As detailed or required for finished appearance.
  2. Special Shapes: In addition to conventional corner bead and control joints, provide U-bead at exposed panel edges.
  3. Products:

- a. Same manufacturer as framing materials.
  - b. Phillips Manufacturing Co: [www.phillipsmfg.com/#sle](http://www.phillipsmfg.com/#sle).
  - c. Trim-tex, Inc: [www.trim-tex.com/#sle](http://www.trim-tex.com/#sle).
  - d. Substitutions: See Section 016000 - Product Requirements.
- C. Beads, Joint Accessories, and Other Trim: ASTM C1047, rigid plastic, galvanized steel, or rolled zinc, unless noted otherwise.
  - 1. Architectural Reveal Beads:
    - a. Reveal Depth: 1/4 inch (6 mm).
    - b. Reveal Width: 1/4 inch (6 mm).
    - c. Products:
      - 1) Phillips Manufacturing Co; J-400 Reveal Trim: [www.phillipsmfg.com/#sle](http://www.phillipsmfg.com/#sle).
      - 2) Substitutions: See Section 016000 - Product Requirements.
  - 2. Expansion Joints:
    - a. Type: V-shaped metal with factory-installed protective tape.
- D. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
  - 1. Paper Tape: 2 inch (50 mm) wide, creased paper tape for joints and corners, except as otherwise indicated.
- E. Screws for Fastening of Gypsum Panel Products to Cold-Formed Steel Studs Less than 0.033 inches (0.84 mm) in Thickness and Wood Members: ASTM C1002; self-piercing tapping screws, corrosion-resistant.
- F. Screws for Fastening of Gypsum Panel Products to Steel Members from 0.033 to 0.112 inch (0.84 to 2.84 mm) in Thickness: ASTM C954; steel drill screws, corrosion-resistant.
- G. Nails for Attachment to Wood Members: ASTM C514.
- H. Anchorage to Substrate: Tie wire, nails, screws, and other metal supports, of type and size to suit application; to rigidly secure materials in place.
- I. Adhesive for Attachment to Wood, ASTM C557 and Metal:

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that project conditions are appropriate for work of this section to commence.

### **3.02 SHAFT WALL INSTALLATION**

- A. Shaft Wall Framing: Install in accordance with manufacturer's installation instructions.
- B. Shaft Wall Liner: Cut panels to accurate dimensions and install sequentially between special friction studs.

### **3.03 FRAMING INSTALLATION**

- A. Metal Framing: Install in accordance with AISI S220 and manufacturer's instructions.
- B. Studs: Space studs at 16 inches on center (at 406 mm on center).
  - 1. Extend partition framing to structure where indicated and to ceiling in other locations.
  - 2. Partitions Terminating at Ceiling: Attach ceiling runner securely to ceiling track in accordance with manufacturer's instructions.
  - 3. Partitions Terminating at Structure: Attach top runner to structure, maintain clearance between top of studs and structure, and connect studs to track using specified mechanical devices in accordance with manufacturer's instructions; verify free movement of top of stud connections; do not leave studs unattached to track.
- C. Openings: Reinforce openings as required for weight of doors or operable panels, using not less than double studs at jambs.
- D. Blocking: Install wood blocking for support of:
  - 1. Framed openings.

2. Wall-mounted cabinets.
3. Wall-mounted door hardware.
4. Monitors.
5. Cabinets and counters.

### **3.04 ACOUSTIC ACCESSORIES INSTALLATION**

- A. Acoustic Insulation: Place tightly within spaces, around cut openings, behind and around electrical and mechanical items within partitions, and tight to items passing through partitions.
- B. Acoustic Sealant: Install in accordance with manufacturer's instructions.
  1. Place two beads continuously on substrate before installation of perimeter framing members.
  2. Place continuous bead at perimeter of each layer of gypsum board.
  3. Seal around all penetrations by conduit, pipe, ducts, and rough-in boxes, except where firestopping is provided.

### **3.05 BOARD INSTALLATION**

- A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
- B. Single-Layer Nonrated: Install gypsum board in most economical direction, with ends and edges occurring over firm bearing.
- C. Double-Layer, Nonrated: Use gypsum board for first layer, placed parallel to framing or furring members, with ends and edges occurring over firm bearing. Use glass mat faced gypsum board at exterior walls and at other locations as indicated. Place second layer perpendicular to framing or furring members. Offset joints of second layer from joints of first layer.
- D. Fire-Resistance-Rated Construction: Install gypsum board in strict compliance with requirements of assembly listing.
- E. Exposed Gypsum Board in Interior Wet Areas: Seal joints, cut edges, and holes with water-resistant sealant.
- F. Installation on Metal Framing: Use screws for attachment of gypsum board except face layer of nonrated double-layer assemblies, which may be installed by means of adhesive lamination.

### **3.06 INSTALLATION OF TRIM AND ACCESSORIES**

- A. Control Joints: Place control joints consistent with lines of building spaces and as indicated.
- B. Corner Beads: Install at external corners, using longest practical lengths.
- C. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

### **3.07 JOINT TREATMENT**

- A. Paper Faced Gypsum Board: Use paper joint tape, embed with drying type joint compound and finish with drying type joint compound.
- B. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
  1. Level 5: Walls and ceilings to receive semi-gloss or gloss paint finish and other areas specifically indicated.
  2. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
  3. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish.
  4. Level 1: Fire-resistance-rated wall areas above finished ceilings, whether or not accessible in the completed construction.
  5. Level 0: Surfaces indicated to be finished in later stage of project.
- C. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes.
  1. Feather coats of joint compound so that camber is maximum 1/32 inch (0.8 mm).



2. Taping, filling, and sanding are not required at surfaces behind adhesive applied ceramic tile and fixed cabinetry.
- D. Where Level 5 finish is indicated, spray apply high build drywall surfacer over entire surface after joints have been properly treated; achieve a flat and tool mark-free finish.
- E. Fill and finish joints and corners of cementitious backing board as recommended by manufacturer.

### **3.08 TOLERANCES**

- A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet (3 mm in 3 m) in any direction.

### **3.09 CLEANING**

- A. Clean \_\_\_\_\_.

### **3.10 PROTECTION**

- A. Protect installed gypsum board assemblies from subsequent construction operations.

**END OF SECTION**

## **SECTION 095100 ACOUSTICAL CEILINGS**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Suspended metal grid ceiling system.
- B. Acoustical units.

#### **1.02 RELATED REQUIREMENTS**

- A. Section 072100 - Thermal Insulation: Acoustical insulation.

#### **1.03 REFERENCE STANDARDS**

- A. ASTM C635/C635M - Standard Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings; 2022.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023.
- C. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials; 2022.
- D. ASTM E1264 - Standard Classification for Acoustical Ceiling Products; 2022.

#### **1.04 ADMINISTRATIVE REQUIREMENTS**

- A. Sequence work to ensure acoustical ceilings are not installed until building is enclosed, sufficient heat is provided, dust generating activities have terminated, and overhead work is completed, tested, and approved.
- B. Do not install acoustical units until after interior wet work is dry.

#### **1.05 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on suspension system components and acoustical units.
- C. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- D. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements, for additional provisions.
  - 2. Extra Acoustical Units: Quantity equal to 5 percent of total installed.

#### **1.06 FIELD CONDITIONS**

- A. Maintain uniform temperature of minimum 60 degrees F (16 degrees C), and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.

### **PART 2 PRODUCTS**

#### **2.01 MANUFACTURERS**

- A. Acoustic Tiles/Panels:
  - 1. Armstrong World Industries, Inc: [www.armstrongceilings.com/#sle](http://www.armstrongceilings.com/#sle).
  - 2. CertainTeed Corporation: [www.certainteed.com/ceilings-and-walls/#sle](http://www.certainteed.com/ceilings-and-walls/#sle).
  - 3. Rockfon: [www.rockfon.com/#sle](http://www.rockfon.com/#sle).
  - 4. USG Corporation: [www.usg.com/ceilings/#sle](http://www.usg.com/ceilings/#sle).
  - 5. Substitutions: See Section 016000 - Product Requirements.
- B. Wood Veneer Acoustic Panels:
  - 1. CertainTeed Corporation: [www.certainteed.com/ceilings-and-walls/#sle](http://www.certainteed.com/ceilings-and-walls/#sle).
  - 2. Murano Acoustics USA, by Bartley Group, Inc: [www.muranoacousticsusa.com/#sle](http://www.muranoacousticsusa.com/#sle).
- C. Suspension Systems:
  - 1. Same as for acoustical units.

2. Substitutions: See Section 016000 - Product Requirements.

## **2.02 ACOUSTICAL UNITS**

- A. Acoustical Units - General: ASTM E1264, Class A.
- B. Acoustical Panels, Type 1: Painted mineral fiber, with the following characteristics:
  1. Classification: ASTM E1264 Type III.
  2. Size: 24 by 24 inches (610 by 610 mm).
  3. Thickness: 5/8 inch (16 mm).
  4. Panel Edge: Square Tegular.
  5. Suspension System: Exposed grid.
  6. Products:
    - a. Armstrong World Industries, Inc; Ultima: [www.armstrongceilings.com/#sle](http://www.armstrongceilings.com/#sle).
    - b. USG Corporation; Eclipse Acoustical Panels: [www.usg.com/ceilings/#sle](http://www.usg.com/ceilings/#sle).
    - c. Substitutions: See Section 016000 - Product Requirements.

## **2.03 SUSPENSION SYSTEM(S)**

- A. Metal Suspension Systems - General: Complying with ASTM C635/C635M; die cut and interlocking components, with perimeter moldings, hold down clips, stabilizer bars, clips, and splices as required.
- B. Exposed Suspension System: Hot-dipped galvanized steel grid with steel cap.
  1. Structural Classification: Intermediate-duty, when tested in accordance with ASTM C635/C635M.
  2. Profile: Tee; 15/16 inch (24 mm) face width.
  3. Finish: Baked enamel.
  4. Color: White.
  5. Products:
    - a. CertainTeed Corporation; 15/16" EZ Stab Classic System: [www.certainteed.com/ceilings-and-walls/#sle](http://www.certainteed.com/ceilings-and-walls/#sle).
    - b. USG Corporation; Donn Brand ZXLA 15/16 inch Acoustical Suspension System: [www.usg.com/ceilings/#sle](http://www.usg.com/ceilings/#sle).
    - c. Substitutions: See Section 016000 - Product Requirements.

## **2.04 ACCESSORIES**

- A. Support Channels and Hangers: Galvanized steel; size and type to suit application, seismic requirements, and ceiling system flatness requirement specified.
- B. Hanger Wire: 12 gauge, 0.08 inch (2 mm) galvanized steel wire.
- C. Perimeter Moldings: Same metal and finish as grid.
- D. Acoustical Insulation: Specified in Section 072100.
  1. Thickness: 6 inch (152 mm).
  2. Size: To fit acoustical suspension system.
- E. Gypsum Board: Fire rated type; 5/8 inch (16 mm) thick, ends and edges square, paper faced.
- F. Touch-up Paint: Type and color to match acoustical and grid units.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that layout of hangers will not interfere with other work.

### **3.02 INSTALLATION - SUSPENSION SYSTEM**

- A. Install suspension system in accordance with manufacturer's instructions and as supplemented in this section.

- B. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.
- C. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.
  - 1. Use longest practical lengths.
- D. Suspension System, Non-Seismic: Hang suspension system independent of walls, columns, ducts, pipes and conduit. Where carrying members are spliced, avoid visible displacement of face plane of adjacent members.
- E. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.
- F. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.
- G. Support fixture loads using supplementary hangers located within 6 inches (152 mm) of each corner, or support components independently.
- H. Do not eccentrically load system or induce rotation of runners.
- I. Form expansion joints as detailed. Form to accommodate plus or minus 1 inch (25 mm) movement. Maintain visual closure.
- J. Install light fixture boxes constructed of gypsum board above light fixtures in accordance with fire rated assembly requirements and light fixture ventilation requirements.

### **3.03 INSTALLATION - ACOUSTICAL UNITS**

- A. Install acoustical units in accordance with manufacturer's instructions.
- B. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.
- C. Fit border trim neatly against abutting surfaces.
- D. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.
- E. Cutting Acoustical Units:
  - 1. Make field cut edges of same profile as factory edges.
  - 2. Double cut and field paint exposed reveal edges.
- F. Where round obstructions occur, provide preformed closures to match perimeter molding.
- G. Lay acoustical insulation for a distance of 48 inches (1219 mm) either side of acoustical partitions as indicated.
- H. Install hold-down clips on panels within 20 ft (6 m) of an exterior door.

### **3.04 TOLERANCES**

- A. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet (3 mm in 3 m).
- B. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.

### **3.05 CLEANING**

- A. See Section 017000 - Execution and Closeout Requirements for additional requirements.
- B. Clean surfaces.
- C. Replace damaged or abraded components.

**END OF SECTION**

**SECTION 096500  
RESILIENT FLOORING**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Resilient sheet flooring.
- B. Resilient tile flooring.
- C. Resilient base.
- D. Resilient stair accessories.
- E. Installation accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 033000 - Cast-in-Place Concrete: Restrictions on curing compounds for concrete slabs and floors to receive adhesive-applied resilient flooring.
- B. Section 260539 - Underfloor Raceways for Electrical Systems: Electrical floor cover plates for installation of resilient flooring specified in this section.

**1.03 REFERENCE STANDARDS**

- A. ASTM F710 - Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring; 2022.
- B. ASTM F1066 - Standard Specification for Vinyl Composition Floor Tile; 2023.
- C. ASTM F1700 - Standard Specification for Solid Vinyl Floor Tile; 2020.
- D. ASTM F1861 - Standard Specification for Resilient Wall Base; 2021.
- E. ASTM F2169 - Standard Specification for Resilient Stair Treads; 2015 (Reapproved 2020).

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Shop Drawings: Indicate seaming plans and floor patterns.
- D. Verification Samples: Submit two samples, 6 by 6 inch (\_\_\_ by \_\_\_ mm) in size illustrating color and pattern for each resilient flooring product specified.
- E. Certification: Prior to installation of flooring, submit written certification by flooring manufacturer and adhesive manufacturer that condition of subfloor is acceptable.
- F. Installer's Qualification Statement.
- G. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements, for additional provisions.
  - 2. Extra Flooring Material: 10 square feet (\_\_\_\_ square meters) of each type and color.
  - 3. Extra Wall Base: 25 linear feet (\_\_\_\_ linear meters) of each type and color.
  - 4. Extra Stair Materials: Quantity equivalent to 5 percent of each type and color.

**1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in installing specified flooring with minimum three years documented experience.

**1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Maintain temperature in storage area between 55 degrees F (13 degrees C) and 90 degrees F (72 degrees C).
- B. Protect roll materials from damage by storing on end.

## **1.07 FIELD CONDITIONS**

- A. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F (21 degrees C) to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F (13 degrees C).

## **PART 2 PRODUCTS**

### **2.01 SHEET FLOORING**

### **2.02 TILE FLOORING**

- A. Vinyl Composition Tile: Homogeneous, with color extending throughout thickness.
  - 1. Manufacturers:
    - a. Armstrong Flooring; Standard Execelon Imperial Texture: [www.armstrongflooring.com/#sle](http://www.armstrongflooring.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.
  - 2. Minimum Requirements: Comply with ASTM F1066, of Class corresponding to type specified.
  - 3. Size: 4 by 36 inch (\_\_\_ by \_\_\_ mm).
  - 4. Thickness: 0.125 inch (3.2 mm).
  - 5. Color: As indicated on drawings.

### **2.03 STAIR COVERING**

- A. Stair Treads with Integral Risers: Rubber; full height of riser, full width and depth of tread in one piece; tapered thickness.
  - 1. Manufacturers:
    - a. Flexco Corporation; Heavy Duty One-Piece Tread with Riser: [www.flexcofloors.com/#sle](http://www.flexcofloors.com/#sle).
    - b. Johnsonite, a Tarkett Company: [www.johnsonite.com](http://www.johnsonite.com).
    - c. Mannington Commercial: [www.manningtoncommercial.com/#sle](http://www.manningtoncommercial.com/#sle).
    - d. Roppe Corporation: [www.roppe.com/#sle](http://www.roppe.com/#sle).
    - e. Substitutions: See Section 016000 - Product Requirements.
  - 2. Nosing: Square.
  - 3. Tread Texture: Raised.
  - 4. Color: As indicated on drawings.
- B. Stair Nosings: 1-1/2 inch (38 mm) horizontal return, 1-1/8 inch (28.5 mm) vertical return, full width of stair tread in one piece.
  - 1. Manufacturers:
    - a. Balco, Inc; IllumiTread Egress: [www.balcousa.com/#sle](http://www.balcousa.com/#sle).
    - b. Roppe Corporation: [www.roppe.com/#sle](http://www.roppe.com/#sle).
    - c. Substitutions: See Section 016000 - Product Requirements.
  - 2. Material: Rubber.
  - 3. Color: To match stair treads.

### **2.04 RESILIENT BASE**

- A. Resilient Base: ASTM F1861, Type TS, rubber, vulcanized thermoset; style as scheduled.
  - 1. Manufacturers:
    - a. Flexco Corporation; Base Sculptures: [www.flexcofloors.com/#sle](http://www.flexcofloors.com/#sle).
    - b. Johnsonite, a Tarkett Company: [www.johnsonite.com/#sle](http://www.johnsonite.com/#sle).
    - c. Mannington Commercial: [www.manningtoncommercial.com/#sle](http://www.manningtoncommercial.com/#sle).
    - d. Roppe Corporation; Contours Profiled Wall Base System: [www.roppe.com/#sle](http://www.roppe.com/#sle).
    - e. Substitutions: See Section 016000 - Product Requirements.
  - 2. Height: 4 inches (100 mm).
  - 3. Thickness: 0.125 inch (3.2 mm).
  - 4. Finish: Satin.
  - 5. Length: Roll.

6. Color: As indicated on drawings.
7. Accessories: Premolded external corners and internal corners.

## **2.05 ACCESSORIES**

- A. Subfloor Filler: White premix latex; type recommended by adhesive material manufacturer.
- B. Primers, Adhesives, and Seam Sealer: Waterproof; types recommended by flooring manufacturer.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.
- B. Cementitious Subfloor Surfaces: Verify that substrates are ready for resilient flooring installation by testing for moisture and alkalinity (pH).
  1. Obtain instructions if test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.

### **3.02 INSTALLATION - GENERAL**

- A. Starting installation constitutes acceptance of subfloor conditions.
- B. Install in accordance with manufacturer's written instructions.

### **3.03 INSTALLATION - SHEET FLOORING**

- A. Lay flooring with joints and seams parallel to longer room dimensions, to produce minimum number of seams. Lay out seams to avoid widths less than 1/3 of roll width; match patterns at seams.

### **3.04 INSTALLATION - TILE FLOORING**

- A. Mix tile from container to ensure shade variations are consistent when tile is placed, unless otherwise indicated in manufacturer's installation instructions.

### **3.05 INSTALLATION - RESILIENT BASE**

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches (45 mm) between joints.
- B. Install base on solid backing. Bond tightly to wall and floor surfaces.

### **3.06 INSTALLATION - STAIR COVERINGS**

- A. Adhere over entire surface. Fit accurately and securely.

**END OF SECTION**

## **SECTION 096813 TILE CARPETING**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Carpet tile, fully adhered.
- B. Removal of existing carpet tile.

#### **1.02 RELATED REQUIREMENTS**

#### **1.03 REFERENCE STANDARDS**

- A. ASTM E648 - Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source; 2019a, with Editorial Revision (2020).
- B. ASTM F710 - Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring; 2022.
- C. CRI (GLP) - Green Label Plus Testing Program - Certified Products; Current Edition.
- D. NFPA 253 - Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source; 2023.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; sizes, patterns, colors available, and method of installation.
- C. Shop Drawings: Indicate layout of joints.
- D. Manufacturer's Installation Instructions: Indicate special procedures, perimeter conditions requiring special attention, and suggested schedule for cleaning.
- E. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements, for additional provisions.
  - 2. Extra Carpet Tiles: Quantity equal to 5 percent of total installed of each color and pattern installed.

#### **1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in installing carpet tile with minimum three years documented experience and approved by carpet tile manufacturer.

#### **1.06 FIELD CONDITIONS**

### **PART 2 PRODUCTS**

#### **2.01 MANUFACTURERS**

- A. Tile Carpeting: Match Existing
  - 1. Substitutions: See Section 016000 - Product Requirements.

#### **2.02 MATERIALS**

- A. Tile Carpeting: Tufted, manufactured in one color dye lot.
  - 1. Product: \_\_\_\_\_ manufactured by \_\_\_\_\_.
  - 2. Tile Size: 18 by 18 inch (450 by 450 mm), nominal.
  - 3. Color: Match Existing.
  - 4. Pattern: Match Existing.
  - 5. Critical Radiant Flux: Minimum of 0.22 watts/sq cm, when tested in accordance with ASTM E648 or NFPA 253.

#### **2.03 ACCESSORIES**

- A. Edge Strips: Embossed aluminum, color as selected by Architect.
- B. Adhesives:



1. Compatible with materials being adhered; maximum VOC content of 50 g/L; CRI (GLP) certified; in lieu of labeled product, independent test report showing compliance is acceptable.

C. Carpet Tile Adhesive: Recommended by carpet tile manufacturer; releasable type.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that subfloor surfaces are smooth and flat within tolerances specified for that type of work and are ready to receive carpet tile.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive carpet tile.
- C. Verify that subfloor surfaces are dust-free and free of substances that could impair bonding of adhesive materials to subfloor surfaces.
- D. Cementitious Subfloor Surfaces: Verify that substrates are ready for flooring installation by testing for moisture and alkalinity (pH).
  1. Test as Follows:
    - a. Alkalinity (pH): ASTM F710.
  2. Obtain instructions if test results are not within limits recommended by flooring material manufacturer and adhesive materials manufacturer.
- E. Verify that required floor-mounted utilities are in correct location.

### **3.02 PREPARATION**

- A. Remove existing carpet tile.
- B. Prepare floor substrates as recommended by flooring and adhesive manufacturers.
- C. Remove subfloor ridges and bumps. Fill minor or local low spots, cracks, joints, holes, and other defects with subfloor filler.
- D. Apply, trowel, and float filler to achieve smooth, flat, hard surface. Prohibit traffic until filler is cured.
- E. Vacuum clean substrate.

### **3.03 INSTALLATION**

- A. Starting installation constitutes acceptance of subfloor conditions.
- B. Install carpet tile in accordance with manufacturer's instructions.
- C. Blend carpet from different cartons to ensure minimal variation in color match.
- D. Cut carpet tile clean. Fit carpet tight to intersection with vertical surfaces without gaps.
- E. Lay carpet tile in square pattern, with pile direction parallel to next unit, set parallel to building lines.
- F. Trim carpet tile neatly at walls and around interruptions.
- G. Complete installation of edge strips, concealing exposed edges.

### **3.04 CLEANING**

- A. See Section 017000 - Execution and Closeout Requirements for additional requirements.
- B. Remove excess adhesive without damage, from floor, base, and wall surfaces.
- C. Clean and vacuum carpet surfaces.

**END OF SECTION**

## **SECTION 099123 INTERIOR PAINTING**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
- D. Do Not Paint or Finish the Following Items:
  - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
  - 2. Items indicated to receive other finishes.
  - 3. Items indicated to remain unfinished.
  - 4. Fire rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
  - 5. Stainless steel, anodized aluminum, bronze, terne-coated stainless steel, and lead items.
  - 6. Marble, granite, slate, and other natural stones.
  - 7. Floors, unless specifically indicated.
  - 8. Ceramic and other tiles.
  - 9. Brick, architectural concrete, cast stone, integrally colored plaster, and stucco.
  - 10. Glass.
  - 11. Concealed pipes, ducts, and conduits.

#### **1.02 RELATED REQUIREMENTS**

- A. Section 055000 - Metal Fabrications: Shop-primed items.
- B. Section 055100 - Metal Stairs: Shop-primed items.
- C. Section 099113 - Exterior Painting.
- D. Section 099600 - High-Performance Coatings.

#### **1.03 REFERENCE STANDARDS**

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency; current edition.
- B. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials; 2020.
- C. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual; Current Edition.
- D. SSPC-SP 1 - Solvent Cleaning; 2015, with Editorial Revision (2016).
- E. SSPC-SP 6 - Commercial Blast Cleaning; 2007.
- F. SSPC-SP 13 - Surface Preparation of Concrete; 2018.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
  - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g., "alkyd enamel").
  - 2. MPI product number (e.g., MPI #47).
  - 3. Cross-reference to specified paint system products to be used in project; include description of each system.

- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches (216 by 279 mm) in size, illustrating range of colors available for each finishing product specified.
  - 1. Where sheen is specified, submit samples in only that sheen.
  - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens not required.
- D. Manufacturer's Instructions: Indicate special surface preparation procedures.
- E. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- F. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements, for additional provisions.
  - 2. Extra Paint and Finish Materials: 1 gal (4 L) of each color; from the same product run, store where directed.
  - 3. Label each container with color in addition to the manufacturer's label.

### **1.05 QUALITY ASSURANCE**

- A. Applicator Qualifications: Company specializing in performing the type of work specified with minimum 5 years experience and approved by manufacturer.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F (7 degrees C) and a maximum of 90 degrees F (32 degrees C), in ventilated area, and as required by manufacturer's instructions.

### **1.07 FIELD CONDITIONS**

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply materials when relative humidity exceeds 85 percent, at temperatures less than 5 degrees F (3 degrees C) above the dew point, or to damp or wet surfaces.
- D. Minimum Application Temperatures for Paints: 50 degrees F (10 degrees C) for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 fc (860 lux) measured mid-height at substrate surface.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Provide paints and finishes from the same manufacturer to the greatest extent possible.
- B. Paints:
  - 1. Behr Process Corporation: [www.behr.com/#sle](http://www.behr.com/#sle).
  - 2. Pittsburgh Paints: [www.ppgpaints.com/#sle](http://www.ppgpaints.com/#sle).
  - 3. Sherwin-Williams Company: [www.sherwin-williams.com/#sle](http://www.sherwin-williams.com/#sle).
- C. Primer Sealers: Same manufacturer as top coats.
- D. Substitutions: See Section 016000 - Product Requirements.

### **2.02 PAINTS AND FINISHES - GENERAL**

- A. Paints and Finishes: Ready-mixed, unless intended to be a field-catalyzed paint.

1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
  2. Supply each paint material in quantity required to complete entire project's work from a single production run.
  3. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Volatile Organic Compound (VOC) Content:
1. Provide paints and finishes that comply with the most stringent requirements specified in the following:
    - a. 40 CFR 59, Subpart D--National Volatile Organic Compound Emission Standards for Architectural Coatings.
  2. Determination of VOC Content: Testing and calculation in accordance with 40 CFR 59, Subpart D (EPA Method 24), exclusive of colorants added to a tint base and water added at project site; or other method acceptable to authorities having jurisdiction.
- C. Colors: As indicated on drawings.

## **2.03 PAINT SYSTEMS - INTERIOR**

- A. Paint I-OP - Interior Surfaces to be Painted, Unless Otherwise Indicated: Including gypsum board.
1. Two top coats and one coat primer.
  2. Top Coat(s): High Performance Architectural Interior Latex; MPI #138, 139, 140, 141, or 142.
  3. Top Coat(s): Interior Latex; MPI #43, 44, 52, 53, 54, or 114.
- B. Paint I-OP-MD-DT - Medium Duty Door/Trim: For surfaces subject to frequent contact by occupants, including metals and wood:
1. Medium duty applications include doors and door frames.
  2. Two top coats and one coat primer.
  3. Top Coat(s): Interior Epoxy-Modified Latex; MPI #115 or 215.
    - a. Products:
      - 1) Pittsburgh Paints Aquapon WB EP Two-Component Waterborne Epoxy Coating, 98E-1/98E-100 Series, Semi-Gloss. (MPI #215)
      - 2) Sherwin-Williams Waterbased Catalyzed Epoxy, Gloss.
      - 3) Substitutions: See Section 016000 - Product Requirements

## **PART 3 EXECUTION**

### **3.01 PREPARATION**

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- D. Seal surfaces that might cause bleed through or staining of topcoat.
- E. Gypsum Board: Fill minor defects with filler compound. Spot prime defects after repair.
- F. Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried; sand between coats. Back prime concealed surfaces before installation.
- G. Wood Doors to be Field-Finished: Seal wood door top and bottom edge surfaces with clear sealer.

### **3.02 APPLICATION**

- A. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- B. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- C. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- D. Sand wood and metal surfaces lightly between coats to achieve required finish.
- E. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- F. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

**END OF SECTION**

**SECTION 102600  
WALL AND DOOR PROTECTION**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Corner guards.

**1.02 REFERENCE STANDARDS**

- A. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics; 2010 (Reapproved 2018).
- B. ASTM D543 - Standard Practices for Evaluating the Resistance of Plastics to Chemical Reagents; 2021.
- C. ASTM F476 - Standard Test Methods for Security of Swinging Door Assemblies; 2023.
- D. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).

**1.03 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.

**1.04 WARRANTY**

- A. See Section 017800 - Closeout Submittals for additional warranty requirements.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Corner Guards:
  - 1. Koroseal Interior Products; Sizes & Prices Koroseal Korogard G100 Corner Guards | Aluminum Retainer - #A136: [www.koroseal.com/#sle](http://www.koroseal.com/#sle).
  - 2. Substitutions: See Section 016000 - Product Requirements.

**2.02 PERFORMANCE CRITERIA**

- A. Impact Strength: Unless otherwise noted, provide protection products and assemblies that have been successfully tested for compliance with applicable provisions of ASTM D256 and/or ASTM F476.
- B. Chemical and Stain Resistance: Unless otherwise noted, provide protection products and assemblies with chemical and stain resistance complying with applicable provisions of ASTM D543.
- C. Fungal Resistance: Unless otherwise noted, provide protection products and assemblies which pass ASTM G21 testing.

**2.03 PRODUCT TYPES**

- A. Corner Guards - Surface Mounted:
  - 1. Material: High impact vinyl with full height extruded aluminum retainer.
  - 2. Width of Wings: 2 inches (51 mm).
  - 3. Corner: Square.
  - 4. Color: match wall color.
  - 5. Length: One piece.

**2.04 FABRICATION**

- A. Fabricate components with tight joints, corners and seams.

**PART 3 EXECUTION**

**3.01 EXAMINATION**

- A. Verify that rough openings, concealed blocking, and anchors are correctly sized and located.
- B. Start of installation constitutes acceptance of project conditions.

### **3.02 INSTALLATION**

- A. Install components in accordance with manufacturer's instructions, level and plumb, secured rigidly in position to supporting construction.
- B. Position 48" corner guard 4 inches (102 mm) above finished floor.

### **3.03 CLEANING**

- A. Clean wall and door protection items of excess adhesive, dust, dirt, and other contaminants.

### **3.04 SCHEDULE**

- A. All exposed corners, see drawings.

**END OF SECTION**

**SECTION 104400  
FIRE PROTECTION SPECIALTIES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Fire extinguishers.
- B. Fire extinguisher cabinets.
- C. Accessories.

**1.02 RELATED REQUIREMENTS**

- A. Section 061000 - Rough Carpentry: Wood blocking product and execution requirements.

**1.03 REFERENCE STANDARDS**

- A. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2013a (Reapproved 2017).
- B. NFPA 10 - Standard for Portable Fire Extinguishers; 2022.

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- C. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
- D. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- E. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

**1.05 FIELD CONDITIONS**

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Fire Extinguishers:
  - 1. Provided by Owner.
- B. Fire Extinguisher Cabinets and Accessories:
  - 1. Larsen's Manufacturing Co: [www.larsensmfg.com/#sle](http://www.larsensmfg.com/#sle).
  - 2. No substitutions.

**2.02 FIRE EXTINGUISHERS**

- A. Fire Extinguishers - Provided by Owner.

**2.03 FIRE EXTINGUISHER CABINETS**

- A. Fire Rating: Listed and labeled in accordance with ASTM E814 requirements for fire resistance rating of walls where being installed.
- B. Cabinet Construction: Non-fire rated.
  - 1. Formed primed steel sheet; 0.036 inch (0.9 mm) thick base metal.
- C. Fire Rated Cabinet Construction: Match fire resistance rating of walls where being installed.
  - 1. Steel; double wall or outer and inner boxes with 5/8 inch (15.9 mm) thick fire barrier material.
- D. Cabinet Configuration: Semi-recessed type.
  - 1. Size to accommodate accessories.
  - 2. Projected Trim: Returned to wall surface.



- 3. Provide cabinet enclosure with right angle inside corners and seams, and with formed perimeter trim and door stiles.
- E. Door: 0.036 inch (0.9 mm) metal thickness, reinforced for flatness and rigidity with nylon catch. Hinge doors for 180 degree opening with two butt hinges.
- F. Door Glazing: Acrylic plastic, clear, 1/8 inch (3 mm) thick, flat shape and set in resilient channel glazing gasket.
- G. Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- H. Fabrication: Weld, fill, and grind components smooth.
- I. Finish of Cabinet Exterior Trim and Door: Baked enamel, white color.
- J. Finish of Cabinet Interior: White colored enamel.

#### **2.04 ACCESSORIES**

- A. Extinguisher Brackets: Formed steel, galvanized and enamel finished.
- B. Lettering: FIRE EXTINGUISHER decal, or vinyl self-adhering, pre-spaced black lettering in accordance with authorities having jurisdiction (AHJ).

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

#### **3.02 INSTALLATION**

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets plumb and level in wall openings, 40 inches (\_\_\_\_ mm) from finished floor to inside bottom of cabinet.
- C. Secure rigidly in place.
- D. Place extinguishers in cabinets.

**END OF SECTION**

## **SECTION 123600 COUNTERTOPS**

### **PART 1 GENERAL**

#### **1.01 SECTION INCLUDES**

- A. Countertops for architectural cabinet work.
- B. Wall-hung counters

#### **1.02 RELATED REQUIREMENTS**

#### **1.03 REFERENCE STANDARDS**

- A. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards, 2nd Edition; 2014, with Errata (2016).
- B. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards; 2021, with Errata.
- C. ISFA 2-01 - Classification and Standards for Solid Surfacing Material; 2013.
- D. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.
- E. PS 1 - Structural Plywood; 2023.

#### **1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Test Reports: Chemical resistance testing, showing compliance with specified requirements.
- C. Certificate: Submit labels and certificates required by quality assurance and quality control programs.

#### **1.05 QUALITY ASSURANCE**

- A. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience.
- B. Quality Certification:
  - 1. Provide labels or certificates indicating that the installed work complies with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS) requirements for grade or grades specified.
  - 2. Provide designated labels on shop drawings as required by certification program.
  - 3. Provide designated labels on installed products as required by certification program.
  - 4. Submit certifications upon completion of installation that verifies this work is in compliance with specified requirements.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

#### **1.07 FIELD CONDITIONS**

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

### **PART 2 PRODUCTS**

#### **2.01 COUNTERTOPS**

- A. Quality Standard: Custom Grade, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
- B. Solid Surfacing Countertops: Solid surfacing sheet or plastic resin casting over continuous substrate.
  - 1. Flat Sheet Thickness: 1/2 inch (12 mm), minimum.

2. Solid Surfacing Sheet and Plastic Resin Castings: Complying with ISFA 2-01 and NEMA LD 3; acrylic or polyester resin, mineral filler, and pigments; homogenous, non-porous and capable of being worked and repaired using standard woodworking tools; no surface coating; color and pattern consistent throughout thickness.
  - a. Finish on Exposed Surfaces: Matte, gloss rating of 5 to 20.
3. Other Components Thickness: 1/2 inch (12 mm), minimum.
4. Back and End Splashes: Same sheet material, square top; minimum 4 inches (102 mm) high.
5. Fabricate in accordance with manufacturer's standard requirements.

## **2.02 MATERIALS**

- A. Wood-Based Components:
  1. Wood fabricated from old growth timber is not permitted.
- B. Plywood for Supporting Substrate: PS 1 Exterior Grade, A-C veneer grade, minimum 5-ply; minimum 3/4 inch (19 mm) thick; join lengths using metal splines.
- C. Adhesives: Chemical resistant waterproof adhesive as recommended by manufacturer of materials being joined.
- D. Joint Sealant: Mildew-resistant silicone sealant, white.

## **2.03 ACCESSORIES**

- A. Fixed Top-Mounted Countertop Support Brackets:
  1. Material: Steel.
  2. Finish: Manufacturer's standard, factory-applied, textured powder coat.
  3. Color: Black.

## **2.04 FABRICATION**

- A. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.
  1. Join lengths of tops using best method recommended by manufacturer.
  2. Fabricate to overhang fronts and ends of cabinets 1 inch (25 mm) except where top butts against cabinet or wall.
  3. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.
- B. Provide back/end splash wherever counter edge abuts vertical surface unless otherwise indicated.
  1. Secure to countertop with concealed fasteners and with contact surfaces set in waterproof glue.
  2. Height: 4 inches (102 mm), unless otherwise indicated.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- C. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.

### **3.02 PREPARATION**

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

### **3.03 INSTALLATION**

- A. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.

- B. Seal joint between back/end splashes and vertical surfaces.

#### **3.04 CLEANING**

- A. Clean countertops surfaces thoroughly.

#### **3.05 PROTECTION**

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

**END OF SECTION**